## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of PWS ID#			PWS ID# 41 0	0557		
Month/Year		07/2025 Entry Point:		WTP-A Req		equired Minimum	ired Minimum Chlorine Residual 0.20 mg/L	
Date	Time	Sources(		Lowest residual a	free chlorine at entry point to n system (mg/L)		Notes	
1	08:00	Well Field		0.77	r system (mg/L)			
2	08:00	"		0.87				
3	08:00	II .		0.59				
4	08:00	"		0.91				
5	08:00	"		0.84				
6	08:00	"		1.31				
7	08:00	"		0.91				
8	08:00	п		0.74				
9	08:00	II .		1.04				
10	08:00	"		0.73				
11	08:00	"		0.77				
12	08:00	"		0.49				
13	08:00	"		1.08				
14	08:00	"		1.31				
15	08:00	"		0.85				
16	08:00	"		0.76				
17	08:00	"		0.55				
18	08:00	"		0.89				
19	08:00	"		0.97				
20	08:00	п		0.85				
21	08:00	"		0.78				
22	08:00	"		0.83				
23	08:00	"		0.63				
24	08:00	"		0.59				
25	08:00	"		0.65				
26	08:00	II .		0.80				
27	08:00	II .		0.76				
28	08:00	"		0.84				
29	08:00	"		0.84				
30	08:00	"		0.72				
31	08:00	"		0.57				
		al ever less than the request period until the requ			Yes urs	XNo		
GWS Serving 3,300 or Fewer			GWS Serving More than 3,300					
if yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time this reporting month? Yes				Date continues monitoring equipment failed	
Attach those results and submit them with this form			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service Yes No  attach grab sample results and submit them with this form.			9	Date it was returned to service:	
Printed Name: Jon Hodgkins			Title: Operations Supervisor			Operator C	Operator Certification #: 09290	
Signature: Jon Hodglink			Phone #: (503) 593-6723				OR Small Groundwater System	
Date: 07/05/2025								