

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year APRIL / 2021 Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:08 AM	#4	0.68 MGL	C.M.E.
2	8:15 AM	#4	0.67 MGL	C.M.E.
3	8:20 AM	#4	0.71 MGL	C.M.E.
4	10:00 AM	#2, 4	0.75 MGL	C.M.E.
5	8:21 AM	#4	0.76 MGL	C.M.E.
6	9:09 AM	#1, 4	0.67 MGL	C.M.E.
7	8:18 AM	#4	0.82 MGL	C.M.E.
8	8:16 AM	#2, 4, 6	0.89 MGL	C.M.E.
9	7:56 AM	#4	0.63 MGL	C.M.E.
10	9:43 AM	#4	0.77 MGL	C.M.E.
11	9:38 AM	#4	0.75 MGL	C.M.E.
12	9:08 AM	#4	0.71 MGL	C.M.E.
13	10:24 AM	#4	0.96 MGL	C.M.E.
14	8:23 AM	#4	0.73 MGL	C.M.E.
15	8:21 AM	#4	0.70 MGL	C.M.E.
16	8:54 AM	#4	0.70 MGL	C.M.E.
17	7:40 AM	#4	0.74 MGL	C.M.E.
18	11:15 AM	#4	0.81 MGL	C.M.E.
19	7:46 AM	none.	0.95 MGL	C.M.E.
20	8:14 AM	#4	0.90 MGL	C.M.E.
21	8:19 AM	#4	0.94 MGL	C.M.E.
22	8:08 AM	#2, 4, 6	0.90 MGL	C.M.E.
23	8:14 AM	#4	0.90 MGL	C.M.E.
24	9:28 AM	#4	0.76 MGL	C.M.E.
25	9:35 AM	#4	0.77 MGL	C.M.E.
26	8:24 AM	#4	0.74 MGL	C.M.E.
27	8:09 AM	#1, 2, 4, 6	0.75 MGL	C.M.E.
28	8:00 AM	#4	0.88 MGL	C.M.E.
29	8:16 AM	#4	0.66 MGL	C.M.E.
30	8:01 AM	#4	0.80 MGL	C.M.E.
31				C.M.E.

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L?</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>

Printed Name: FLOYD STALEMP Title: UTILITY WORKER III Operator Certification #: T-08998  
 Signature: [Signature] Phone #: (541) 974-3942 OR  
 Date: 4/30/2021 Small Groundwater System

DWP  
PO BOX 14450