

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge PWS ID# 41- 00582  
 Month/Year FEB, / 2022 Entry Point: EPA Wellfield Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:13/Am	# 4	2.68 mg/L	C M E
2	10:31/Am	# 4	2.72 mg/L	C M E
3	9:30/Am	# 4	2.82 mg/L	C M E
4	10:18 AM	# 4	0.82 mg/L	CME
5	7:00 AM	# 4	0.76 mg/L	CME
6	7:49 AM	# 4	0.68 mg/L	CME
7	8:42/Am	# 4	2.68 mg/L	C M E
8	8:42 AM	# 4	0.70 mg/L	CME
9	8:42 AM	# 2, 4+6	0.58 mg/L	CME
10	9:00 am	# 2, 4+6	0.61 mg/L	CME
11	8:57 am	# 4	0.60 mg/L	CME
12	10:00 AM	# 4	0.84 mg/L	CME
13	9:15 AM	# 4	0.92 mg/L	CME
14	9:25/Am	# 1, 4	2.80 mg/L	CME
15	9:50/Am	# 4	2.72 mg/L	CME
16	9:11/Am	# 2, 4	2.60 mg/L	CME
17	9:24 AM	# 1, 2 & 4	0.66 mg/L	CME
18	9:18 AM	# 1, 2, 4	0.66 mg/L	CME
19	9:26 AM	# 1	0.69 mg/L	CME
20	9:38 AM	# 2, 4	0.67 mg/L	C.M.E
21	9:35 AM	# 4	0.73 mg/L	C.M.E
22	9:13/Am	# 2, 4	2.93 mg/L	C M E
23	8:40 AM	# 4	0.68 mg/L	CME
24	8:28 AM	# 4	0.76 mg/L	CME
25	8:45 AM	# 4	0.71 mg/L	CME
26	9:30 AM	# 4	0.76 mg/L	CME
27	10:30 AM	# 4	0.62 mg/L	CME
28	8:35 AM	# 4	0.64 mg/L	CME
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L?                  Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed:                  / /</p> <p>Date it was returned to service:                  / /</p>
---	---	---

Printed Name: Floyd Stalcup Title: UTILITY WORKER III Operator Certification #: T-08998  
 Signature: Floyd Stalcup Phone #: (541) 974 3942 OR  
 Date: 3 / 1 / 2022 Small Groundwater System

DWP  
PO Box 14450