

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year Aug. / 2022 Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:17Am	# 4	0.59 mg/L	CME
2	8:25Am	# 2,4,6	0.58 mg/L	CME
3	9:06Am	# 4	0.57 mg/L	CME
4	8:40Am	# 2,4,6	0.62 mg/L	CME
5	9:15Am	# 4	0.60 mg/L	CME
6	9:38Am	# 2,4,6	0.62 mg/L	CME
7	10:18Am	# 2,4,6	0.63 mg/L	CME
8	9:48Am	# 4	0.61 mg/L	CME
9	9:20Am	# 1,2,4,6	0.60 mg/L	CME
10	9:24Am	# 2,4,6	0.61 mg/L	CME
11	9:25Am	# 4	0.59 mg/L	CME
12	8:30Am	# 4	0.58 mg/L	CME
13	9:07Am	# 1,2,4,6	0.63 mg/L	CME
14	8:45Am	# 1,4,6	0.60 mg/L	CME
15	8:35Am	# 1, 2, 4	0.69 mg/L	CME
16	9:12Am	# 1, 2, 4	0.59 mg/L	CME
17	1:00pm	# 4	0.60 mg/L	C.M.E.
18	1:00pm	# 1, 2, 4	0.58 mg/L	CME
19	9:25Am	# 4	0.58 mg/L	CME
20	10:55am	# 2,4+6	0.63 mg/L	CME
21	10:45am	# 4	0.56 mg/L	CME
22	9:15Am	# 2,4,6	0.58 mg/L	CME
23	9:50Am	# 4	0.55 mg/L	CME
24	8:46Am	# 2,4,6	0.56 mg/L	CME
25	8:21Am	# 2+4	0.52 mg/L	CME
26	10:13Am	# 2,4,6	0.52 mg/L	CME
27	9:10Am	# 4	0.58 mg/L	CME
28	9:25Am	# 2,4,6	0.62 mg/L	CME
29	10:15Am	# 4	0.65 mg/L	CME
30	8:52Am	# 1,4,6	0.58 mg/L	CME
31	9:18Am	# 1,4,6	0.58 mg/L	CME

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /  
 Date it was returned to service:

/ /

Printed Name: Floyd Stalcup

Title: Crew Leader

Operator Certification #: T-08998

Signature: Floyd Stalcup

Phone #: (541) 974-3942

OR

Date: 9/1/2022

Small Groundwater System

DWP