

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year March 2023 Entry Point: EPA

Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:29 AM	#4	1.30 MGL	CME
2	8:26 AM	#4	0.78 MGL	CME
3	9:20 AM	#4	0.66 MGL	CME
4	9:05 AM	#2, 4, 6	0.66 MGL	CME
5	9:10 AM	#4	0.74 MGL	CME
6	9:10 AM	#4	0.65 MGL	CME
7	8:43 AM	#4	0.65 MGL	CME
8	8:24 AM	#1 #4 #6	0.74 MGL	CME
9	9:40 AM	#4	1.28 MGL	CME
10	9:40 AM	#4	1.11 MGL	CME
11	9:45 AM	#4	1.16 MGL	CME
12	11:28 AM	#4	1.27 MGL	CME
13	8:29 AM	#4	1.23 MGL	CME
14	8:49 AM	#4	1.11 MGL	CME
15	8:48 AM	#1, 4, 6	1.28 MGL	CME
16	8:22	#4	1.34 MGL	CME
17	9:15 AM	#4	1.28 MGL	CME
18	10:15 AM	#4	1.05 MGL	CME
19	8:00 AM	#4	1.03 MGL	CME
20	10:00 AM	#4	1.05 MGL	CME
21	8:19	#4	1.07 MGL	CME
22	9:00 AM	#1 #4 #6	1.13 MGL	CME
23	9:31 AM	#1 #4 #6	1.11 MGL	CME
24	9:21 AM	#4	1.15 MGL	CME
25	10:40 AM	#2, 4, 6	1.06 MGL	CME
26	10:25 AM	#2, 4, 6	1.05 MGL	CME
27	8:43 AM	#4	1.09 MGL	CME
28	8:55 AM	#4	1.05 MGL	CME
29	9:42 AM	#1 #4	1.03 MGL	CME
30	9:50 AM	#1 #4 #6	1.03 MGL	CME
31	8:18 AM	#1 #4 #6	0.99 MGL	CME

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /  
 Date it was returned to service: / /

Printed Name: Travess Howerly

Title: Utility Worker 2/DRC

Operator Certification #: 933316

Signature: Travess Howerly

Phone #: (541) 852-0821

OR

Date: 3/31/2023

Small Groundwater System

DWP