

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year April / 2025 Entry Point: EPA

Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:40	#4	0.65 mg/L	C.M.E
2	8:20	#4	0.51 mg/L	C.M.E
3	8:17	#4	0.66 mg/L	C.M.E
4	9:35	#4	0.55 mg/L	C.M.E
5	9:40	#2,4,6	0.97 mg/L	C.M.E
6	10:00am	#4	0.70 mg/L	C.M.E
7	9:15 AM	1,4	0.46 mg/L	C.M.E
8	8:05 AM	2,4,6	0.64 mg/L	C.M.E
9	9:31 AM	2,4,6	0.45 mg/L	C.M.E
10	8:38	2,4	0.87 mg/L	C.M.E
11	9:48	4	0.67 mg/L	C.M.E
12	9:39 AM	2,4,6	0.67 mg/L	C.M.E
13	9:44 AM	4	0.49 mg/L	C.M.E
14	10:31 AM	1,4	0.74 mg/L	C.M.E
15	9:20 AM	2,4,6	0.64 mg/L	C.M.E
16	9:40 AM	2,4,6	0.44 mg/L	C.M.E
17	9:41 AM	1,4	0.65 mg/L	C.M.E
18	9:38 AM	4	0.66 mg/L	C.M.E
19	10:39	2,4	0.65 mg/L	C.M.E
20	11:50	4	0.46 mg/L	C.M.E
21	8:19	2,4,6	0.53 mg/L	C.M.E
22	9:47	2,4,6	0.70 mg/L	C.M.E
23	8:29	4	0.60 mg/L	C.M.E
24	8:46	2,4,6	0.48 mg/L	C.M.E
25	9:46	2,4,6	0.45 mg/L	C.M.E
26	8:19	4	0.61 mg/L	C.M.E
27	7:50	2,4,6	0.65 mg/L	C.M.E
28	9:00	4	0.63 mg/L	C.M.E
29	8:09	4	0.60 mg/L	C.M.E
30	9:05	2,4,6	0.63 mg/L	C.M.E
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☒ No
If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Clint Whitney

Title: D.R.C

Signature: [Signature]

Phone #: (541) 554-7698

Date: 5/17/2025

Operator Certification #: T-08971

OR

Small Groundwater System ☐

RWP