

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year June / 2025 Entry Point: EPA

Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:00	#4		
2	8:54	#2, 4, 6	0.74 mg/L	C.M.E
3	8:18	#4	0.85 mg/L	C.M.E
4	7:57	#2, 4, 6	0.85 mg/L	C.M.E
5	7:58	2, 4, 6	0.94 mg/L	C.M.E
6	8:14	2, 4	0.92 mg/L	C.M.E
7	9:57	2, 4, 6	0.86 mg/L	C.M.E
8	7:48	2, 4, 6	0.79 mg/L	C.M.E
9	8:08	2, 4, 6	0.83 mg/L	C.M.E
10	8:40	4	0.82 mg/L	C.M.E
11	8:47	2, 4, 6	0.80 mg/L	C.M.E
12	8:24	2, 4, 6	0.82 mg/L	C.M.E
13	9:00	2, 4, 6	0.84 mg/L	C.M.E
14	9:30	4	0.87 mg/L	C.M.E
15	11:00	4	1.14 mg/L	C.M.E
16	9:02	4	0.77 mg/L	C.M.E
17	10:20	2, 4	0.74 mg/L	C.M.E
18	11:42	4	1.11 mg/L	C.M.E
19	8:45	4	0.73 mg/L	C.M.E
20	10:18	2, 4	0.76 mg/L	C.M.E
21	7:59	#4	0.79 mg/L	C.M.E
22	6:27	2, 4, 6	0.86 mg/L	C.M.E
23	8:40	2, 4, 6	0.83 mg/L	C.M.E
24	8:45	4	0.84 mg/L	C.M.E
25	8:14	4	0.74 mg/L	C.M.E
26	9:34	4	0.80 mg/L	C.M.E
27	9:12	2, 4, 6	0.72 mg/L	C.M.E
28	7:55	2, 4, 6	0.76 mg/L	C.M.E
29	8:45	2, 4, 6	1.11 mg/L	C.M.E
30	8:25	1, 2, 4, 6	0.95 mg/L	C.M.E
31			0.78 mg/L	C.M.E

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No  
If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

Date it was returned to service:

Printed Name: Clint Whitney

Title: D.R.C

Signature: Clint Whitney

Phone #: (541) 534-7698

Operator Certification #: T-08971

OR

Date: 7/7/2025

Small Groundwater System ☐

DWP