

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year    /   

Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:56	#4	0.66 mg/L	CME
2	9:00	4	0.99 MGL	CME
3	8:30	4	0.36 MGL	CME
4	8:30	4	0.37 MGL	CME
5	8:40	4	0.72 MGL	CME
6	8:10	4	0.54 MGL	CME
7	8:01	2,4,6	0.26 mg/L	CME
8	8:20	2,4,6	0.83 mg/L	CME
9	8:40	4	0.54 mg/L	CME
10	8:45	2,4,6	0.84 MGL	CME
11	9:15	2,4	0.95 MGL	CME
12	9:30	4	0.58 MGL	CME
13	9:30	4	0.53 MGL	CME
14	8:30	4	0.36 MGL	CME
15	9:10	4	0.48 MGL	CME
16	8:42	4	0.22 mg/L	CME
17	8:25	4	0.45 mg/L	CME
18	8:32	4,2,6	0.53 mg/L	CME
19	8:16	4	0.49 mg/L	CME
20	9:35	4	0.35 mg/L	CME
21	10:00	2,4,6	0.36 mg/L	CME
22	8:00	4	0.34 mg/L	CME
23	8:45	4	0.70 mg/L	CME
24	8:32	4	0.68 mg/L	CME
25	8:25	4	0.68 MGL	CME
26	8:00	4	0.70 MGL	CME
27	8:45	4	0.67 MGL	CME
28	8:52	4	0.73 MGL	CME
29	8:55	4	0.69 MGL	CME
30	9:10	4	0.59 MGL	CME
31	9:00	4	0.61 MGL	CME

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.20 mg/L?

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /  
Date it was returned to service:

/ /

Printed Name: Isaiah Mark

Title: Crew Leader

Operator Certification #: T-48108

Signature: [Signature]

Phone #: (541) 650-1227

OR

Date: 4/1/2026

Small Groundwater System

DWP