

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year MAY / 2021 Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:10AM	# 2, 4	0.85	C.M.E.
2	10:15AM	# 2, 4	0.86	C.M.E.
3	8:21AM	# 1, 2, 4	0.83	C.M.E.
4	8:17AM	# 4	0.84	C.M.E.
5	7:58AM	# 4	0.70	C.M.E.
6	8:08AM	# 2, 4, 6	0.77	C.M.E.
7	8:45AM	# 4	0.67	C.M.E.
8	10:01AM	# 4	0.67	C.M.E.
9	9:54AM	# 2, 4, 6	0.79	C.M.E.
10	8:46AM	# 4	0.66	C.M.E.
11	7:43AM	# 1, 4, 6	0.81	C.M.E.
12	8:16AM	# 1, 2, 4	0.82	C.M.E.
13	8:44AM	# 1, 2, 4	0.82	C.M.E.
14	8:05AM	# 4	0.66	C.M.E.
15	8:25AM	# 4	0.77 mg/L	C.M.E.
16	8:50AM	# 1, 2, 4	0.83 mg/L	C.M.E.
17	9:58AM	# 2, 4, 6	0.70 mg/L	C.M.E.
18	9:37AM	# 4	0.65 mg/L	C.M.E.
19	9:15AM	# 4	0.75 mg/L	C.M.E.
20	9:15AM	# 4	0.57 mg/L	C.M.E.
21	10:12AM	# 4	0.94 mg/L	C.M.E.
22	9:30AM	# 4	0.88 mg/L	C.M.E.
23	10:26AM	# 4	0.57 mg/L	C.M.E.
24	1:39PM	NONE	0.69 mg/L	C.M.E.
25	8:48AM	# 4	0.61 mg/L	C.M.E.
26	9:07AM	# 4	0.55 mg/L	C.M.E.
27	8:50AM	# 4	0.54 mg/L	C.M.E.
28	10:00AM	# 4	0.63 mg/L	C.M.E.
29	8:50AM	# 4	0.61 mg/L	C.M.E.
30	8:28AM	# 1, 2, 4	0.63 mg/L	C.M.E.
31	9:11AM	# 1, 2, 4	0.57 mg/L	C.M.E.

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Floyd Stalcup

Signature: Floyd Stalcup

Date: 6 / 1 / 2021

Title: UTILITY WORKER III

Phone #: (541) 974-3742

Operator Certification #: T-08998

OR

Small Groundwater System