

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year OCT / 2021 Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:24 AM	#4	0.64 mg/L	CME
2	9:19 AM	#4	0.60 mg/L	CME
3	10:19 AM	#1, 2, 4	0.65 mg/L	CME
4	11:43 AM	#2, 4	0.69 mg/L	CME
5	8:43 AM	#4	0.65 mg/L	CME
6	9:29 AM	#1, 2, 4, 6	0.50 mg/L	CME
7	9:03 AM	#4	0.69 mg/L	C.M.E.
8	8:35 AM	#2, 4	0.86 mg/L	C.M.E.
9	9:00 AM	#4	0.80 mg/L	C.M.E.
10	9:37 AM	#2, 4, 6	0.74 mg/L	CME
11	10:05 AM	#4	0.73 mg/L	CME
12	9:50 AM	#1, 4	0.77 mg/L	CME
13	9:29 AM	#4	0.65 mg/L	CME
14	9:59 AM	#4	0.64 mg/L	CME
15	8:55 AM	#1, 2 + 4	0.63 mg/L	CME
16	10:49 AM	#4	0.63 mg/L	CME
17	9:07 AM	1, 2 & 4	0.74 mg/L	CME
18	8:55 AM	#2, 4, 6	0.60 mg/L	CME
19	9:12 AM	#4	0.62 mg/L	CME
20	10:01 AM	#4	0.60 mg/L	CME
21	8:44 AM	#2, 4, 6	0.59 mg/L	CME
22	9:10 AM	#4	0.62 mg/L	CME
23	10:15 AM	#4	0.61 mg/L	CME
24	9:21 AM	#4	0.62 mg/L	CME
25	9:56 AM	#4	0.63 mg/L	CME
26	8:56 AM	#4	0.74 mg/L	C.M.E.
27	9:10 AM	#4	0.61 mg/L	CME
28	9:21 AM	#1, 2, 4	0.75 mg/L	CME
29	9:00 AM	#4	0.70 mg/L	CME
30	8:00 AM	#4	0.71 mg/L	CME
31	8:20 AM	#4	0.71 mg/L	CME

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?
 Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____
 Date it was returned to service: _____ / _____ / _____

Printed Name: Floyd Stalcup

Title: WT:1, TYPWRKER III

Operator Certification #: T-08998

Signature: Floyd Stalcup

Phone #: (541) 974-3942

OR

Date: 11 / 1 / 2021

Small Groundwater System

DWP
PO Box 14450