

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year MARCH /2022

Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00AM	#4	0.61 mg/L	CME
2	10:13AM	#4	0.67 mg/L	CME
3	9:30AM	#4	0.69 mg/L	CME
4	8:36AM	# 1, 2, 4	2.65 mg/L	CME
5	8:28AM	# 4	2.54 mg/L	CME
6	8:49AM	# 4	2.55 mg/L	CME
7	8:41AM	#4	0.75 mg/L	CME
8	8:39AM	#4	0.80 mg/L	CME
9	10:50AM	#4	0.84 mg/L	CME
10	9:04AM	#4	2.75 mg/L	CME
11	8:54AM	#4	0.78 mg/L	CME
12	10:15AM	#4	0.72 mg/L	CME
13	10:40AM	#4	0.74 mg/L	CME
14	8:59AM	#1, 2+4	0.87 mg/L	CME
15	8:31AM	#4	0.70 mg/L	C.M.E.
16	8:50AM	#4	0.74 mg/L	C.M.E.
17	9:00AM	#4	0.77 mg/L	C.M.E.
18	9:04AM	#1, 4	0.95 mg/L	C.M.E.
19	9:20AM	# 1, 3, 4	0.94 mg/L	CME
20	9:40AM	#4	0.80 mg/L	CME
21	9:12AM	#4	0.80 mg/L	C.M.E.
22	8:37AM	#4	0.80 mg/L	C.M.E.
23	8:30AM	#4	0.75 mg/L	C.M.E.
24	8:13AM	#4	2.88 mg/L	CME
25	9:03AM	#4	0.72 mg/L	C.M.E.
26	8:34AM	#4	0.82 mg/L	C.M.E.
27	8:57AM	#4	0.82 mg/L	C.M.E.
28	8:35AM	#4	0.73 mg/L	CME
29	9:25AM	#4	0.87 mg/L	CME
30	8:20AM	#1, 2+4	0.85 mg/L	CME
31	8:38AM	#1, 2+4	0.90 mg/L	CME

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: Floyd Stalcup  
 Signature: Floyd Stalcup  
 Date: 4 / 1 / 2022

Title: UTILITY WORKER III  
 Phone #: (541) 974-3942

Operator Certification #: T-08998  
 OR  
 Small Groundwater System

DWP  
 PO Box 17450