

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City Of Oakridge

PWS ID# 41- 00582

Month/Year OCT. / 2022 Entry Point: EPA Wellfield

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:53am	#1, 4, 6	0.59 MGL	CME
2	9:48am	#4	0.58 MGL	CME
3	8:34am	#4	0.63 MGL	CME
4	7:55am	#1, 2, 4	0.66 MGL	CME
5	9:25/Am	# 4	0.66 mg/L	CME
6	9:53/Am	# 1, 2, 4	0.65 mg/L	CME
7	11:22/Am	# 4	0.62 mg/L	CME
8	8:55/Am	# 4	0.55 mg/L	CME
9	8:34/Am	# 4	0.56 mg/L	CME
10	9:35/Am	# 4	0.58 mg/L	CME
11	10:00/Am	# 4	0.63 mg/L	CME
12	9:19/Am	# 1, 4	0.61 mg/L	CME
13	8:44/Am	# 2, 4, 6	0.62 mg/L	CME
14	10:01/Am	# 4	0.59 mg/L	CME
15	9:17/Am	# 2, 4, 6	0.63 MGL	CME
16	9:45/Am	# 2, 4, 6	0.62 MGL	CME
17	10:31/Am	# 4	0.70 mg/L	CME
18	9:40/Am	# 2, 4, 6	0.58 mg/L	CME
19	8:33/Am	# 4	0.58 mg/L	CME
20	9:09/Am	# 4	0.62 MGL	CME
21	9:05/Am	# 4	0.63 mg/L	CME
22	10:50am	# 2, 6	0.66 mg/L	CME
23	9:32am	# 4	0.61 mg/L	CME
24	10:16/Am	# 4	0.54 mg/L	CME
25	9:46/Am	# 1, 2, 4	0.72 mg/L	CME
26	9:39/Am	# 4	0.56 mg/L	CME
27	9:54/Am	# 1, 2, 4, 6	0.81 mg/L	CME
28	10:30am	#4	0.74 mg/L	CME
29	8:45am	#4	0.75 mg/L	CME
30	9:47am	#4	0.76 MGL	CME
31	9:22am	#4	0.78 mg/L	CME

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: Floyd Stalcup

Title: C.F.W. LEADER

Operator Certification #: T-08998

Signature: Floyd Stalcup

Phone #: (541) 974-3942

OR

Date: 11 / 1 / 2022

Small Groundwater System

DWP