

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name HILAND WC - ILLAHE GOLF CLUB ESTATES

PWS ID# 4 1 00755

Month/Year Feb/2021 Entry Point: A

Required Minimum Residual 0.33 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:00P	Well 1&2	0.85	
2	4:00P	Well 1&2	0.71	
3	4:00P	Well 1&2	0.60	
4	4:00P	Well 1&2	0.63	
5	4:00P	Well 1&2	0.66	
6	4:00P	Well 1&2	0.71	
7	4:00P	Well 1&2	0.79	
8	4:00P	Well 1&2	0.81	
9	4:00P	Well 1&2	0.83	
10	4:00P	Well 1&2	0.79	
11	4:00P	Well 1&2	0.78	
12	4:00P	Well 1&2	0.61	
13	4:00P	Well 1&2	0.48	
14	4:00P	Well 1&2	0.36	
15	4:00P	Well 1&2	0.35	
16	4:00P	Well 1&2	0.33	
17	4:00P	Well 1&2	0.30	
18	4:00P	Well 1&2	0.54	
19	4:00P	Well 1&2	0.73	
20	4:00P	Well 1&2	0.76	
21	4:00P	Well 1&2	0.81	
22	4:00P	Well 1&2	0.89	
23	4:00P	Well 1&2	0.95	
24	4:00P	Well 1&2	0.80	
25	4:00P	Well 1&2	0.77	
26	4:00P	Well 1&2	0.73	
27	4:00P	Well 1&2	0.71	
28	4:00P	Well 1&2	0.75	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.33 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

Attach those results and submit them with this form.

N/A

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No N/A

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No N/A

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Melvin Olson

Title: DRC

Signature: \_\_\_\_\_



Phone #: (503) 312-9206

Date: 03 / 06 / 2021

Operator Certification #: 3413

OR

Small Groundwater System