

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name HILAND WC - ILLAHE GOLF CLUB ESTATES

PWS ID# 4 1 00755

Month/Year Apr/2022 Entry Point: A

Required Minimum Residual 0.33 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:00P	Well 1&2	0.62	
2	4:00P	Well 1&2	0.73	
3	4:00P	Well 1&2	0.78	
4	4:00P	Well 1&2	0.83	
5	4:00P	Well 1&2	0.86	
6	4:00P	Well 1&2	0.80	
7	4:00P	Well 1&2	0.74	
8	4:00P	Well 1&2	0.71	
9	4:00P	Well 1&2	0.67	
10	4:00P	Well 1&2	0.55	
11	4:00P	Well 1&2	0.51	
12	4:00P	Well 1&2	0.57	
13	4:00P	Well 1&2	0.66	
14	4:00P	Well 1&2	0.71	
15	4:00P	Well 1&2	0.76	
16	4:00P	Well 1&2	0.79	
17	4:00P	Well 1&2	0.81	
18	4:00P	Well 1&2	0.84	
19	4:00P	Well 1&2	0.87	
20	4:00P	Well 1&2	0.94	
21	4:00P	Well 1&2	0.96	
22	4:00P	Well 1&2	0.92	
23	4:00P	Well 1&2	0.90	
24	4:00P	Well 1&2	0.97	
25	4:00P	Well 1&2	0.99	
26	4:00P	Well 1&2	0.90	
27	4:00P	Well 1&2	0.84	
28	4:00P	Well 1&2	0.76	
29	4:00P	Well 1&2	0.84	
30	4:00P	Well 1&2	0.89	
31				

Was the chlorine residual ever less than the required minimum residual of 0.33 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

N/A

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No N/A

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No N/A

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Melvin Olson

Title: DRC

Signature: _____



Phone #: (503) 312-9206

Date: 05 / 05 / 2022

Operator Certification #: 3413

OR

Small Groundwater System