

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name HILAND WC - ILLAHE GOLF CLUB ESTATES

PWS ID# 4 1 00755

Month/Year Jul/2022 Entry Point: A

Required Minimum Residual 0.33 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:00P	Well 1&2	0.53	
2	4:00P	Well 1&2	0.59	
3	4:00P	Well 1&2	0.54	
4	4:00P	Well 1&2	0.51	
5	4:00P	Well 1&2	0.49	
6	4:00P	Well 1&2	0.52	
7	4:00P	Well 1&2	0.57	
8	4:00P	Well 1&2	0.56	
9	4:00P	Well 1&2	0.53	
10	4:00P	Well 1&2	0.50	
11	4:00P	Well 1&2	0.52	
12	4:00P	Well 1&2	0.58	
13	4:00P	Well 1&2	0.64	
14	4:00P	Well 1&2	0.71	
15	4:00P	Well 1&2	0.92	
16	4:00P	Well 1&2	0.94	
17	4:00P	Well 1&2	0.98	
18	4:00P	Well 1&2	1.03	
19	4:00P	Well 1&2	1.06	
20	4:00P	Well 1&2	0.87	
21	4:00P	Well 1&2	0.75	
22	4:00P	Well 1&2	0.74	
23	4:00P	Well 1&2	0.79	
24	4:00P	Well 1&2	0.81	
25	4:00P	Well 1&2	0.77	
26	4:00P	Well 1&2	0.81	
27	4:00P	Well 1&2	0.88	
28	4:00P	Well 1&2	0.98	
29	4:00P	Well 1&2	0.85	
30	4:00P	Well 1&2	0.71	
31	4:00P	Well 1&2	0.65	

Was the chlorine residual ever less than the required minimum residual of 0.33 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

N/A

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No N/A

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No N/A

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Melvin Olson

Title: DRC

Signature: _____



Phone #: (503) 312-9206

Date: 08 / 05 / 2022

Operator Certification #: 3413

OR

Small Groundwater System