

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name HILAND WC – ILLAHE GOLF CLUB ESTATES

PWS ID# 4 1 00755

Month/Year 06/2025

Entry Point: A

Required Minimum Residual 0.33 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:00P	Well 1&2	0.80	
2	4:00P	Well 1&2	0.83	
3	4:00P	Well 1&2	0.81	
4	4:00P	Well 1&2	0.83	
5	4:00P	Well 1&2	0.82	
6	4:00P	Well 1&2	0.84	
7	4:00P	Well 1&2	0.77	
8	4:00P	Well 1&2	0.72	
9	4:00P	Well 1&2	0.74	
10	4:00P	Well 1&2	0.75	
11	4:00P	Well 1&2	0.77	
12	4:00P	Well 1&2	0.73	
13	4:00P	Well 1&2	0.76	
14	4:00P	Well 1&2	0.79	
15	4:00P	Well 1&2	0.80	
16	4:00P	Well 1&2	0.82	
17	4:00P	Well 1&2	0.80	
18	4:00P	Well 1&2	0.76	
19	4:00P	Well 1&2	0.73	
20	4:00P	Well 1&2	0.71	
21	4:00P	Well 1&2	0.68	
22	4:00P	Well 1&2	0.61	
23	4:00P	Well 1&2	0.55	
24	4:00P	Well 1&2	0.53	
25	4:00P	Well 1&2	0.56	
26	4:00P	Well 1&2	0.57	
27	4:00P	Well 1&2	0.61	
28	4:00P	Well 1&2	0.63	
29	4:00P	Well 1&2	0.68	
30	4:00P	Well 1&2	0.71	

Was the chlorine residual ever less than the required minimum residual of 0.33 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to .33 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Curtis Olson

Title: Compliance Manager

Operator Certification #: 216644

Signature: Curtis Olson

Phone #: (503) 554-8333

OR

Date: 07 /10/ 2025

Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.