

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name PIONEER PARK COOP PWS ID# 41 00784  
 Month/Year 1/2021 Entry Point: \_\_\_\_\_ Required Minimum Residual .20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.30	
2			.30	
3			.40	
4			.30	
5			.20	
6			.50	
7			.50	
8			.50	
9			.50	
10			.50	
11			.50	
12			.50	
13			.40	
14			.40	
15			.40	
16			.40	
17			.40	
18			.40	
19			.50	
20			.35	
21			.40	
22			.40	
23			.40	
24			.40	
25			.40	
26			.40	
27			.35	
28			.40	
29			.40	
30			.40	
31			.35	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/____</p> <p>Date it was returned to service: _____/_____/____</p>
--	--	---

Printed Name: MIKE BEYER Title: \_\_\_\_\_ Operator Certification #: \_\_\_\_\_  
 Signature: \_\_\_\_\_ Phone #: (\_\_\_\_) \_\_\_\_\_ OR  
 Date: 8/1/21 Small Groundwater System