

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name PIONEER PARK CD-OP PWS ID# 41 00784

Month/Year 5/2024 Entry Point: \_\_\_\_\_ Required Minimum Residual .20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.30	
2			.30	
3			.30	
4			.30	
5			.30	
6			.30	
7			.30	
8			.30	
9			.30	
10			.30	
11			.30	
12			.30	
13			.30	
14			.30	
15			.30	
16			.30	
17			.30	
18			.30	
19			.30	
20			.30	
21			.30	
22			.25	
23			.25	
24			.25	
25			.25	
26			.25	
27			.25	
28			.20	
29			.20	
30			.20	
31			.20	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: MIKE BEYER Title: \_\_\_\_\_ Operator Certification #: \_\_\_\_\_  
 Signature: \_\_\_\_\_ Phone #: (\_\_\_\_) \_\_\_\_\_ OR  
 Date: 6/2/24 Small Groundwater System