

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name <u>PIONEER PARK CO-OP</u>			PWS ID# 41 <u>00784</u>	
Month/Year <u>10/2025</u> Entry Point:			Required Minimum Residual <u>.20 mg/L</u>	
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.30	
2			.30	
3			.30	
4			.30	
5			.30	
6			.30	
7			.30	
8			.30	
9			.30	
10			.30	
11			.30	
12			.30	
13			.30	
14			.30	
15			.30	
16			.30	
17			.25	
18			.25	
19			.25	
20			.25	
21			.25	
22			.25	
23			.25	
24			.25	
25			.20	
26			.20	
27			.20	
28			.25	
29			.25	
30			.30	
31			.30	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No		Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Attach those results and submit them with this form.		Date continuous monitoring equipment failed: _____	
		If yes, were grab samples taken every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No	
		Date it was returned to service: _____	
		Attach grab sample results and submit them with this form.	

Printed Name: MIKE BEYER Title: _____ Operator Certification #: _____

Signature: _____ Phone #: (_____) _____ OR

Date: 10/31/25 Small Groundwater System

December 19, 2012