

Monthly Disinfection Report for Ground Water Systems

System Name Applewood Mobile Home Park

PWS ID# 4 1 00840

Month/Year 10 12024

Entry Point:

Required Minimum Residual ⁴⁰ mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:00 pm	Well House	.83	added 1 gal H ₂ O / 8 aps CL
2	2:30 pm	"	1.07	added 2 gal H ₂ O
3	2:30 pm	"	1.06	" " "
4	2:45 pm	"	.93	
5	3:00 pm	"	.89	
6	3:00 pm	"	.86	
7	2:45 pm	"	.74	
8	2:30 pm	"	.71	added 2 aps CL
9	2:30 pm	"	.94	
10	3:30 pm	"	.74	
11	5:00 pm	"	.70	
12	5:00 pm	"	.77	
13	4:30 pm	EGC 10	.81	
14	2:30 pm	Well House	.66	added 13 gal H ₂ O / 11 aps CL
15	2:30 pm	"	.96	
16	2:30 pm	"	.84	
17	2:30 pm	"	.80	
18	3:30 pm	"	.77	
19	5:00 pm	"	.75	
20	3:00 pm	"	.63	added 2 aps CL
21	2:00 pm	"	.70	
22	3:30 pm	"	.76	
23	2:45 pm	"	.90	
24	2:45 pm	"	.84	
25	3:30 pm	"	.72	added 10 gal H ₂ O / 10 aps CL
26	3:30 pm	"	1.39	added 3 gal H ₂ O
27	3:45 pm	"	1.19	
28	2:30 pm	"	1.16	added 2 gal H ₂ O
29	2:30 pm	"	1.06	added 3 gal H ₂ O
30	2:30 pm	"	.96	
31	2:30 pm	"	.81	

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Drew Arseneaux

Title: Water Tester

Signature: Drew Arseneaux

Phone #: (541) 505-2538

Date: 10/31/2024

Operator Certification #:

OR

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.