

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

System Name Mckenzie Palisades

PWS ID# 41

00923

Month/Year Nov 2022 Entry Point:

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1800	well	0.53	
2	0400	well	0.51	
3	1130	well	0.49	
4	0700	well	0.52	
5	0930	well	0.43	
6	1400	well	0.58	
7	1830	well	0.61	
8	1700	well	0.63	
9	0900	well	0.59	
10	0300	well	0.57	
11	1200	well	0.61	
12	1500	well	0.53	
13	2100	well	0.55	
14	0730	well	0.59	
15	0830	well	0.49	
16	0700	well	0.51	
17	0630	well	0.55	
18	0500	well	0.49	
19	1830	well	0.52	
20	0230	well	0.55	
21	0830	well	0.59	
22	0800	well	0.58	
23	2230	well	0.55	
24	0600	well	0.53	
25	1530	well	0.55	
26	2200	well	0.50	
27	2130	well	0.51	
28	0730	well	0.47	
29	0700	well	0.53	
30	1330	well	0.51	
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /
 Date it was returned to service:

/ /

Printed Name: Lanny S. Sayles

Title:

Signature: [Signature]

Phone #: (541) 206-3976

Operator Certification #: 6085

OR

Date: 12/09/2022

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.