

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

| | | | | | |
|-------------|--|-----------------|--|------------------------------------|--|
| System Name | | City Of Wheeler | | PWS ID# 41 00952 | |
| Month/Year: | | Mar-23 | | Entry Point: EP-C | |
| | | | | Required Minimum Residual 0.2 mg/L | |

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|---------|-----------------------|--|-------------------|
| 1 | 8:00 AM | Foss Road Wells 1 & 2 | 0.63 | Normal Operations |
| 2 | 8:00 AM | Foss Road Wells 1 & 2 | 0.59 | Normal Operations |
| 3 | 8:00 AM | Foss Road Wells 1 & 2 | 0.58 | Normal Operations |
| 4 | 8:00 AM | Foss Road Wells 1 & 2 | 0.61 | Normal Operations |
| 5 | 8:00 AM | Foss Road Wells 1 & 2 | 0.57 | Normal Operations |
| 6 | 8:00 AM | Foss Road Wells 1 & 2 | 0.57 | Normal Operations |
| 7 | 8:00 AM | Foss Road Wells 1 & 2 | 0.65 | Normal Operations |
| 8 | 8:00 AM | Foss Road Wells 1 & 2 | 0.63 | Normal Operations |
| 9 | 8:00 AM | Foss Road Wells 1 & 2 | 0.62 | Normal Operations |
| 10 | 8:00 AM | Foss Road Wells 1 & 2 | 0.60 | Normal Operations |
| 11 | 8:00 AM | Foss Road Wells 1 & 2 | 0.54 | Normal Operations |
| 12 | 8:00 AM | Foss Road Wells 1 & 2 | 0.54 | Normal Operations |
| 13 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations |
| 14 | 8:00 AM | Foss Road Wells 1 & 2 | 0.56 | Normal Operations |
| 15 | 8:00 AM | Foss Road Wells 1 & 2 | 0.56 | Normal Operations |
| 16 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations |
| 17 | 8:00 AM | Foss Road Wells 1 & 2 | 0.51 | Normal Operations |
| 18 | 8:00 AM | Foss Road Wells 1 & 2 | 0.47 | Normal Operations |
| 19 | 8:00 AM | Foss Road Wells 1 & 2 | 0.35 | Normal Operations |
| 20 | 8:00 AM | Foss Road Wells 1 & 2 | 0.61 | Normal Operations |
| 21 | 8:00 AM | Foss Road Wells 1 & 2 | 0.53 | Normal Operations |
| 22 | 8:00 AM | Foss Road Wells 1 & 2 | 0.54 | Normal Operations |
| 23 | 8:00 AM | Foss Road Wells 1 & 2 | 0.58 | Normal Operations |
| 24 | 8:00 AM | Foss Road Wells 1 & 2 | 0.59 | Normal Operations |
| 25 | 8:00 AM | Foss Road Wells 1 & 2 | 0.77 | Normal Operations |
| 26 | 8:00 AM | Foss Road Wells 1 & 2 | 0.77 | Normal Operations |
| 27 | 8:00 AM | Foss Road Wells 1 & 2 | 0.62 | Normal Operations |
| 28 | 8:00 AM | Foss Road Wells 1 & 2 | 0.79 | Normal Operations |
| 29 | 8:00 AM | Foss Road Wells 1 & 2 | 0.87 | Normal Operations |
| 30 | 8:00 AM | Foss Road Wells 1 & 2 | 0.85 | Normal Operations |
| 31 | 8:00 AM | Foss Road Wells 1 & 2 | 0.79 | Normal Operations |

Was the chlorine residual ever less than the required minimum residual of 0.2mg/L YES NO 0

If yes, what was the longest time period until the required level was restored?

| | |
|--|---|
| <p style="text-align: center;">GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four untail until the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p> | <p style="text-align: center;">GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p style="text-align: center;"> </p> <p style="text-align: center;">Attach grab sample results and submit them with this form.</p> |
|--|---|

| | | |
|---|--|--|
| Printed Name: Daniel L Weitzel Signature: Daniel L Weitzel Date: 4/4/2023 | Title: Treatment DRC Phone#: (503) 812-2727 | Operator Certification #: WD1#7191 / WT2#08183 OR Small Groundwater System |
|---|--|--|