

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name		City Of Wheeler		PWS ID# 41 00952	
Month/Year:		Aug-23		Entry Point: EP-C	
				Required Minimum Residual 0.2 mg/L	

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
2	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
3	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations
4	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
5	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
6	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
7	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
8	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
9	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
10	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
11	8:00 AM	Foss Road Wells 1 & 2	0.59	Normal Operations
12	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations
13	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations
14	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
15	8:00 AM	Foss Road Wells 1 & 2	0.34	Normal Operations
16	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
17	8:00 AM	Foss Road Wells 1 & 2	0.32	Normal Operations
18	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
19	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
21	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
22	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations
23	8:00 AM	Foss Road Wells 1 & 2	0.65	Normal Operations
24	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations
25	8:00 AM	Foss Road Wells 1 & 2	0.66	Normal Operations
26	8:00 AM	Foss Road Wells 1 & 2	0.46	Normal Operations
27	8:00 AM	Foss Road Wells 1 & 2	0.50	Normal Operations
28	8:00 AM	Foss Road Wells 1 & 2	0.51	Normal Operations
29	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
30	8:00 AM	Foss Road Wells 1 & 2	0.44	Normal Operations
31	8:00 AM	Foss Road Wells 1 & 2	0.34	Normal Operations

Was the chlorine residual ever less than the required minimum residual of 0.2mg/L YES NO 0

If yes, what was the longest time period until the required level was restored?

<p style="text-align: center;">GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four untail until the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p>	<p style="text-align: center;">GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p style="text-align: center;"> </p> <p style="text-align: center;">Attach grab sample results and submit them with this form.</p>
--	---

Printed Name: Daniel L Weitzel Signature: Daniel L Weitzel Date: 9/8/2023	Title: Treatment DRC Phone#: (503) 812-2727	Operator Certification #: WD1#7191 / WT2#08183 OR Small Groundwater System
---	--	--