

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name		City Of Wheeler		PWS ID# 41 00952	
Month/Year:		Feb-24		Entry Point: EP-C	
				Required Minimum Residual 0.2 mg/L	
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	8:00 AM	Foss Road Wells 1 & 2	0.54	Normal Operations	
2	8:00 AM	Foss Road Wells 1 & 2	0.55	Normal Operations	
3	8:00 AM	Foss Road Wells 1 & 2	0.55	Normal Operations	
4	8:00 AM	Foss Road Wells 1 & 2	0.54	Normal Operations	
5	8:00 AM	Foss Road Wells 1 & 2	0.53	Normal Operations	
6	8:00 AM	Foss Road Wells 1 & 2	0.53	Normal Operations	
7	8:00 AM	Foss Road Wells 1 & 2	0.52	Normal Operations	
8	8:00 AM	Foss Road Wells 1 & 2	0.53	Normal Operations	
9	8:00 AM	Foss Road Wells 1 & 2	0.56	Normal Operations	
10	8:00 AM	Foss Road Wells 1 & 2	0.52	Normal Operations	
11	8:00 AM	Foss Road Wells 1 & 2	0.57	Normal Operations	
12	8:00 AM	Foss Road Wells 1 & 2	0.57	Normal Operations	
13	8:00 AM	Foss Road Wells 1 & 2	0.52	Normal Operations	
14	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations	
15	8:00 AM	Foss Road Wells 1 & 2	0.46	Normal Operations	
16	8:00 AM	Foss Road Wells 1 & 2	0.46	Normal Operations	
17	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations	
18	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations	
19	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations	
20	8:00 AM	Foss Road Wells 1 & 2	0.65	Normal Operations	
21	8:00 AM	Foss Road Wells 1 & 2	0.67	Normal Operations	
22	8:00 AM	Foss Road Wells 1 & 2	0.65	Normal Operations	
23	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations	
24	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations	
25	8:00 AM	Foss Road Wells 1 & 2	0.32	Normal Operations	
26	8:00 AM	Foss Road Wells 1 & 2	0.52	Normal Operations	
27	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations	
28	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations	
29	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations	
	8:00 AM	Foss Road Wells 1 & 2	0.00	Normal Operations	
	8:00 AM	Foss Road Wells 1 & 2	0.00	Normal Operations	
Was the chlorine residual ever less than the required minimum residual of 0.2mg/L <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO 0					
If yes, what was the longest time period until the required level was restored?					
<p style="text-align: center;">GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four until the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p>		<p style="text-align: center;">GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p style="text-align: center;">Attach grab sample results and submit them with this form.</p>			
<p>Printed Name: Daniel L Weitzel</p> <p>Signature: Daniel L Weitzel</p> <p>Date: 3/5/2024</p>		<p>Title: Treatment DRC</p> <p>Phone#: (503) 812-2727</p>		<p>Operator Certification #: WD1#7191 / WT2#08183</p> <p style="text-align: center;">OR</p> <p style="text-align: center;">Small Groundwater System</p>	