

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

| System Name  |         | City Of Wheeler  |  | PWS ID# 41 00952                                |  |
|--|---------|--|--|---|--|
| Month/Year:  |         | Apr-24   |  | Entry Point: EP-C                               |  |
|  |         |  |  | Required Minimum Residual 0.2 mg/L              |  |
| Date   | Time    | Source(s) in use   | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes   |  |
| 1  | 8:00 AM | Foss Road Wells 1 & 2  | 0.67   | Normal Operations                               |  |
| 2  | 8:00 AM | Foss Road Wells 1 & 2  | 0.68   | Normal Operations                               |  |
| 3  | 8:00 AM | Foss Road Wells 1 & 2  | 0.66   | Normal Operations                               |  |
| 4  | 8:00 AM | Foss Road Wells 1 & 2  | 0.68   | Normal Operations                               |  |
| 5  | 8:00 AM | Foss Road Wells 1 & 2  | 0.65   | Normal Operations                               |  |
| 6  | 8:00 AM | Foss Road Wells 1 & 2  | 0.66   | Normal Operations                               |  |
| 7  | 8:00 AM | Foss Road Wells 1 & 2  | 0.72   | Normal Operations                               |  |
| 8  | 8:00 AM | Foss Road Wells 1 & 2  | 0.68   | Normal Operations                               |  |
| 9  | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 10   | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 11   | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 12   | 8:00 AM | Foss Road Wells 1 & 2  | 0.71   | Normal Operations                               |  |
| 13   | 8:00 AM | Foss Road Wells 1 & 2  | 0.67   | Normal Operations                               |  |
| 14   | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 15   | 8:00 AM | Foss Road Wells 1 & 2  | 0.69   | Normal Operations                               |  |
| 16   | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 17   | 8:00 AM | Foss Road Wells 1 & 2  | 0.67   | Normal Operations                               |  |
| 18   | 8:00 AM | Foss Road Wells 1 & 2  | 0.73   | Normal Operations                               |  |
| 19   | 8:00 AM | Foss Road Wells 1 & 2  | 0.69   | Normal Operations                               |  |
| 20   | 8:00 AM | Foss Road Wells 1 & 2  | 0.70   | Normal Operations                               |  |
| 21   | 8:00 AM | Foss Road Wells 1 & 2  | 0.67   | Normal Operations                               |  |
| 22   | 8:00 AM | Foss Road Wells 1 & 2  | 0.65   | Normal Operations                               |  |
| 23   | 8:00 AM | Foss Road Wells 1 & 2  | 0.63   | Normal Operations                               |  |
| 24   | 8:00 AM | Foss Road Wells 1 & 2  | 0.63   | Normal Operations                               |  |
| 25   | 8:00 AM | Foss Road Wells 1 & 2  | 0.61   | Normal Operations                               |  |
| 26   | 8:00 AM | Foss Road Wells 1 & 2  | 0.65   | Normal Operations                               |  |
| 27   | 8:00 AM | Foss Road Wells 1 & 2  | 0.67   | Normal Operations                               |  |
| 28   | 8:00 AM | Foss Road Wells 1 & 2  | 0.64   | Normal Operations                               |  |
| 29   | 8:00 AM | Foss Road Wells 1 & 2  | 0.59   | Normal Operations                               |  |
| 30   | 8:00 AM | Foss Road Wells 1 & 2  | 0.52   | Normal Operations                               |  |
|  | 8:00 AM | Foss Road Wells 1 & 2  | 0.00   | Normal Operations                               |  |
| Was the chlorine residual ever less than the required minimum residual of 0.2mg/L? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO 0 |         |  |  |   |  |
| If yes, what was the longest time period until the required level was restored?  |         |  |  |   |  |
| GWS Serving 3,300 or Fewer   |         | GWS Serving More than 3,300  |  |   |  |
| If yes, did you monitor every four untail until the residual returned to 0.02 mg/L?  |         | Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO                                   |  | Date continuous monitoring equipment faied: / / |  |
| Attach those results and submit them with this form.   |         | If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO |  | Date it was returned to service: / /            |  |
| Attach grab sample results and submit them with this form.   |         |  |  |   |  |
| Printed Name: Daniel L Weitzel   |         | Title: Treatment DRC   |  | Operator Certification #: WD1#7191 / WT2#08183  |  |
| Signature: Daniel L Weitzel  |         | Phone#:(503) 812-2727  |  | OR  |  |
| Date: 5/7/2024   |         | Small Groundwater System   |  |   |  |