

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name City Of Wheeler		PWS ID# 4 1 0 0 9 5 2	
Month/Year: Nov-24		Entry Point: EP-C Required Minimum Residual 0.2 mg/L	

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
2	8:00 AM	Foss Road Wells 1 & 2	0.66	Normal Operations
3	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
4	8:00 AM	Foss Road Wells 1 & 2	0.66	Normal Operations
5	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
6	8:00 AM	Foss Road Wells 1 & 2	0.65	Normal Operations
7	8:00 AM	Foss Road Wells 1 & 2	0.69	Normal Operations
8	8:00 AM	Foss Road Wells 1 & 2	0.69	Normal Operations
9	8:00 AM	Foss Road Wells 1 & 2	0.66	Normal Operations
10	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
11	8:00 AM	Foss Road Wells 1 & 2	0.59	Normal Operations
12	8:00 AM	Foss Road Wells 1 & 2	0.69	Normal Operations
13	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
14	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
15	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
16	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
17	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
18	8:00 AM	Foss Road Wells 1 & 2	0.63	Normal Operations
19	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.67	Normal Operations
21	8:00 AM	Foss Road Wells 1 & 2	0.67	Normal Operations
22	8:00 AM	Foss Road Wells 1 & 2	0.67	Normal Operations
23	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
24	8:00 AM	Foss Road Wells 1 & 2	0.59	Normal Operations
25	8:00 AM	Foss Road Wells 1 & 2	0.57	Normal Operations
26	8:00 AM	Foss Road Wells 1 & 2	0.58	Normal Operations
27	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
28	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
29	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
30	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations

Was the chlorine residual ever less then the required minimum residual of 0.2mg/L <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, what was the longest time period until the required level was restored?	
GWS Serving 3,300 or Fewer If yes, did you monitor every four untail until the residual returned to 0.02 mg/L? Attach those results and submit them with this form.	GWS Serving More then 3,300 <div style="display: flex; justify-content: space-between;"> <div style="width: 60%;"> Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO Attach grab sample results and submit them with this form. </div> <div style="width: 35%;"> Date continuous monitoring equipment faied: / / Date it was returned to service: / / </div> </div>

Printed Name: Daniel L Weitzel Signature: Daniel L Weitzel Date: 12/2/2024	Title: Treatment DRC Phone#:(503) 812-2727	Operator Certification #: WD1#7191 / WT2#08183 OR Small Groundwater System
--	---	--