

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name City Of Wheeler		PWS ID# 4 1 0 0 9 5 2	
Month/Year: February-2025		Entry Point: EP-C Required Minimum Residual 0.2 mg/L	

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
2	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
3	8:00 AM	Foss Road Wells 1 & 2	0.40	Normal Operations
4	8:00 AM	Foss Road Wells 1 & 2	0.38	Normal Operations
5	8:00 AM	Foss Road Wells 1 & 2	0.41	Normal Operations
6	8:00 AM	Foss Road Wells 1 & 2	0.40	Normal Operations
7	8:00 AM	Foss Road Wells 1 & 2	0.39	Normal Operations
8	8:00 AM	Foss Road Wells 1 & 2	0.44	Normal Operations
9	8:00 AM	Foss Road Wells 1 & 2	0.44	Normal Operations
10	8:00 AM	Foss Road Wells 1 & 2	0.41	Normal Operations
11	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
12	8:00 AM	Foss Road Wells 1 & 2	0.47	Normal Operations
13	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
14	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
15	8:00 AM	Foss Road Wells 1 & 2	0.54	Normal Operations
16	8:00 AM	Foss Road Wells 1 & 2	0.53	Normal Operations
17	8:00 AM	Foss Road Wells 1 & 2	0.49	Normal Operations
18	8:00 AM	Foss Road Wells 1 & 2	0.47	Normal Operations
19	8:00 AM	Foss Road Wells 1 & 2	0.47	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
21	8:00 AM	Foss Road Wells 1 & 2	0.49	Normal Operations
22	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
23	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
24	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
25	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
26	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
27	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
28	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
1	8:00 AM	Foss Road Wells 1 & 2	0.00	Normal Operations
2	8:00 AM	Foss Road Wells 1 & 2	0.00	Normal Operations
3	8:00AM	Foss Road Wells 1 & 2	0.00	Normal Operations

Was the chlorine residual ever less then the required minimum residual of 0.2mg/L ☐ YES ☒ NO

If yes, what was the longest time period untill the required level was restored?

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four untill the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More then 3,300</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 60%;"> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>Attach grab sample results and submit them with this form.</p> </div> <div style="width: 35%;"> <p>Date continuous monitoring equipment faied: / /</p> <p>Date it was returned to service: / /</p> </div> </div>
--	---