System Name	City Of Wheeler		PWS ID#	41 00952
Month/Year:	April-2025	Entry Point: EP-C	Required Minimum Residual 0.2 mg/L	
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
2	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
3	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
4	8:00 AM	Foss Road Wells 1 & 2	0.62	Normal Operations
5	8:00 AM	Foss Road Wells 1 & 2	0.47	Normal Operations
6	8:00 AM	Foss Road Wells 1 & 2	0.45	Normal Operations
7	8:00 AM	Foss Road Wells 1 & 2	0.44	Normal Operations
8	8:00 AM	Foss Road Wells 1 & 2	0.44	Normal Operations
9	8:00 AM	Foss Road Wells 1 & 2	0.49	Normal Operations
10	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
11	8:00 AM	Foss Road Wells 1 & 2	0.47	Normal Operations
12	8:00 AM	Foss Road Wells 1 & 2	0.53	Normal Operations
13	8:00 AM	Foss Road Wells 1 & 2	0.42	Normal Operations
14	8:00 AM	Foss Road Wells 1 & 2	0.49	Normal Operations
15	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
16	8:00 AM	Foss Road Wells 1 & 2	0.32	Normal Operations
17	8:00 AM	Foss Road Wells 1 & 2	0.57	Normal Operations
18	8:00 AM	Foss Road Wells 1 & 2	0.26	Normal Operations
19	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.43	Normal Operations
21	8:00 AM	Foss Road Wells 1 & 2	0.73	Normal Operations
22	8:00 AM	Foss Road Wells 1 & 2	0.74	Normal Operations
23	8:00 AM	Foss Road Wells 1 & 2	0.59	Normal Operations
23	8:00 AM	Foss Road Wells 1 & 2	0.40	Normal Operations
25	8:00 AM	Foss Road Wells 1 & 2	0.60	Normal Operations
26	8:00 AM	Foss Road Wells 1 & 2	0.59	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.61	Normal Operations
28	8:00 AM	Foss Road Wells 1 & 2	0.64	Normal Operations
20	8:00 AM	Foss Road Wells 1 & 2	0.56	Normal Operations
30	8:00 AM	Foss Road Wells 1 & 2	0.56	Normal Operations
30	0.00 AM		0.50	
			YES NO	Ì
If yes, what was th	he longest time period un	tail the required level was restored?		
GWS Serving 3,300 or Fewer		GWS Serving More then 3,300		
f yes, did you monitor every four untail		Did continuous monitoring equipment fail at any time this		
intil the residual returned to 0.02 mg/L?		reporting month? □ YES ☑ NO	l	Date continuous monitoring equipment faied:
Attach those results and submit them with this form.		If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?		Date it was returned to service:
		Attach grab sample results and su		1 1
inted Name: Rick		Title: Treatment DRC	Operator Certification	#: D1-144265 / T1-144265
- //		Phone#:(503) 812-8868 OR		
ate:	5/1/2025		Small Ground	dwater System

## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems