

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

| System Name | | City Of Wheeler | | PWS ID# 41 00952 | |
|---|---------|-----------------------|---|------------------------------------|--|
| Month/Year: | | February-2026 | | Entry Point: EP-C | |
| | | | | Required Minimum Residual 0.2 mg/L | |
| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes | |
| 1 | 8:00 AM | Foss Road Wells 1 & 2 | 0.36 | Normal Operations | |
| 2 | 8:00 AM | Foss Road Wells 1 & 2 | 0.39 | Normal Operations | |
| 3 | 8:00 AM | Foss Road Wells 1 & 2 | 0.40 | Normal Operations | |
| 4 | 8:00 AM | Foss Road Wells 1 & 2 | 0.39 | Normal Operations | |
| 5 | 8:00 AM | Foss Road Wells 1 & 2 | 0.41 | Normal Operations | |
| 6 | 8:00 AM | Foss Road Wells 1 & 2 | 0.40 | Normal Operations | |
| 7 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 8 | 8:00 AM | Foss Road Wells 1 & 2 | 0.44 | Normal Operations | |
| 9 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 10 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 11 | 8:00 AM | Foss Road Wells 1 & 2 | 0.41 | Normal Operations | |
| 12 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations | |
| 13 | 8:00 AM | Foss Road Wells 1 & 2 | 0.44 | Normal Operations | |
| 14 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations | |
| 15 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations | |
| 16 | 8:00 AM | Foss Road Wells 1 & 2 | 0.44 | Normal Operations | |
| 17 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations | |
| 18 | 8:00 AM | Foss Road Wells 1 & 2 | 0.42 | Normal Operations | |
| 19 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations | |
| 20 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 21 | 8:00 AM | Foss Road Wells 1 & 2 | 0.42 | Normal Operations | |
| 22 | 8:00 AM | Foss Road Wells 1 & 2 | 0.41 | Normal Operations | |
| 23 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 24 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 25 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations | |
| 26 | 8:00 AM | Foss Road Wells 1 & 2 | 0.39 | Normal Operations | |
| 27 | 8:00 AM | Foss Road Wells 1 & 2 | 0.38 | Normal Operations | |
| 28 | 8:00 AM | Foss Road Wells 1 & 2 | 0.36 | Normal Operations | |
| | | | | | |
| | | | | | |
| | | | | | |
| Was the chlorine residual ever less than the required minimum residual of 0.2mg/L? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | | |
| If yes, what was the longest time period until the required level was restored? | | | | | |
| <p style="text-align: center;">GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p> | | | <p style="text-align: center;">GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p style="text-align: center;">Attach grab sample results and submit them with this form.</p> | | |
| <p>Printed Name: Rick Rempfer</p> <p>Signature: <i>Rick Rempfer</i></p> <p>Date: 3/4/2026</p> | | | <p>Title: Treatment DRC</p> <p>Phone#: (503) 812-8868</p> <p>Operator Certification #: D1-144265 / T1-144265</p> <p style="text-align: center;">OR</p> <p style="text-align: center;">Small Groundwater System</p> | | |