

City of Manzanita

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

| | | | | | |
|-------------|--|-----------------|--|------------------------------------|--|
| System Name | | City Of Wheeler | | PWS ID# 41 00952 | |
| Month/Year: | | Sep-21 | | Entry Point: EP-C | |
| | | | | Required Minimum Residual 0.2 mg/L | |

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|---------|-----------------------|--|-------------------|
| 1 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations |
| 2 | 8:00 AM | Foss Road Wells 1 & 2 | 0.43 | Normal Operations |
| 3 | 8:00 AM | Foss Road Wells 1 & 2 | 0.44 | Normal Operations |
| 4 | 8:00 AM | Foss Road Wells 1 & 2 | 0.46 | Normal Operations |
| 5 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations |
| 6 | 8:00 AM | Foss Road Wells 1 & 2 | 0.53 | Normal Operations |
| 7 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations |
| 8 | 8:00 AM | Foss Road Wells 1 & 2 | 0.53 | Normal Operations |
| 9 | 8:00 AM | Foss Road Wells 1 & 2 | 0.53 | Normal Operations |
| 10 | 8:00 AM | Foss Road Wells 1 & 2 | 0.51 | Normal Operations |
| 11 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations |
| 12 | 8:00 AM | Foss Road Wells 1 & 2 | 0.54 | Normal Operations |
| 13 | 8:00 AM | Foss Road Wells 1 & 2 | 0.54 | Normal Operations |
| 14 | 8:00 AM | Foss Road Wells 1 & 2 | 0.51 | Normal Operations |
| 15 | 8:00 AM | Foss Road Wells 1 & 2 | 0.50 | Normal Operations |
| 16 | 8:00 AM | Foss Road Wells 1 & 2 | 0.52 | Normal Operations |
| 17 | 8:00 AM | Foss Road Wells 1 & 2 | 0.50 | Normal Operations |
| 18 | 8:00 AM | Foss Road Wells 1 & 2 | 0.47 | Normal Operations |
| 19 | 8:00 AM | Foss Road Wells 1 & 2 | 0.48 | Normal Operations |
| 20 | 8:00 AM | Foss Road Wells 1 & 2 | 0.49 | Normal Operations |
| 21 | 8:00 AM | Foss Road Wells 1 & 2 | 0.50 | Normal Operations |
| 22 | 8:00 AM | Foss Road Wells 1 & 2 | 0.51 | Normal Operations |
| 23 | 8:00 AM | Foss Road Wells 1 & 2 | 0.45 | Normal Operations |
| 24 | 8:00 AM | Foss Road Wells 1 & 2 | 0.51 | Normal Operations |
| 25 | 8:00 AM | Foss Road Wells 1 & 2 | 0.47 | Normal Operations |
| 26 | 8:00 AM | Foss Road Wells 1 & 2 | 0.44 | Normal Operations |
| 27 | 8:00 AM | Foss Road Wells 1 & 2 | 0.50 | Normal Operations |
| 28 | 8:00 AM | Foss Road Wells 1 & 2 | 0.49 | Normal Operations |
| 29 | 8:00 AM | Foss Road Wells 1 & 2 | 0.50 | Normal Operations |
| 30 | 8:00 AM | Foss Road Wells 1 & 2 | 0.49 | Normal Operations |
| 31 | 8:00 AM | Foss Road Wells 1 & 2 | 0.46 | Normal Operations |

Was the chlorine residual ever less than the required minimum residual of 0.2mg/L YES NO
 If yes, what was the longest time period until the required level was restored?

| | |
|---|--|
| <p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four until the residual returned to 0.02 mg/L?</p> <p>Attach those results and submit them with this form.</p> | <p>GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>Attach grab sample results and submit them with this form.</p> |
|---|--|

| | | |
|--|--|--|
| Printed Name: Daniel L Weitzel Signature: Daniel L Weitzel Date: 10/8/2021 | Title: Treatment DRC Phone#: (503) 812-2727 | Operator Certification #: WD1#7191 / WT2#08183 OR Small Groundwater System |
|--|--|--|