

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Leafwood Water Assoc PWS ID# 41 00993
 Month/Year 10/21 Entry Point: Source AA Well Required Minimum Residual 2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:40	a.m.	2	
2	9:30	a.m.	2	
3	8:18	a.m.	2	
4	9:20	a.m.	2	
5	7:58	a.m.	2	
6	8:00	a.m.	2	
7	2:00	p.m.	2	
8	5:00	p.m.	2	
9	4:00	p.m.	2.5	
10	9:10	a.m.	2.5	
11	8:00	a.m.	2	
12	8:00	a.m.	2.5	
13	9:00	a.m.	2.5	
14	8:40	a.m.	2	
15	7:50	a.m.	3	
16	8:15	a.m.	2.5	
17	9:00	a.m.	2	
18	9:30	a.m.	2	
19	8:40	a.m.	2	
20	8:30	a.m.	2	
21	8:00	a.m.	2	
22	7:30	a.m.	2	
23	8:10	a.m.	2.5	
24	8:30	a.m.	2	
25	8:00	a.m.	2	
26	8:30	a.m.	2	
27	8:00	a.m.	2	
28	8:30	a.m.	2	
29	8:30	a.m.	2	
30	8:00	a.m.	2	
31	8:10	a.m.	2	

Was the chlorine residual ever less than the required minimum residual of 2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to <u> </u> mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: <u> </u>/<u> </u>/<u> </u></p> <p>Date it was returned to service: <u> </u>/<u> </u>/<u> </u></p>
---	--	---

Printed Name: Alix Geller Title: Operator Certification #: N/A
 Signature: Alix Geller Phone #: (541) 241-6238 OR
 Date: 10/21/21 Small Groundwater System

