

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

RECEIVED

MAY 03 2023

System Name Leafwood Water Assoc PWS ID# 4100993
 Month/Year 4, 23 Entry Point: Source AA Well Required Minimum Residual 2 mg/L

Certification
Drinking Water Services

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:50	a.m.	0.2	
2	9:00	a.m.	0.2	
3	8:40	am	0.25	
4	8:10	am	0.25	
5	9:00	a.m.	0.2	
6	8:00	a.m.	0.2	
7	8:40	a.m.	0.2	
8	8:45	a.m.	0.2	
9	9:15	am	0.2	
10	10:30	am	0.2	
11	8:30	am	0.2	
12	9:10		0.2	
13	9:20	↓	0.2	
14	8:15		0.2	
15	10:20		0.2	
16	11:00		0.2	
17	11:30		0.2	
18	8:00		0.2	
19	9:30	am	0.2	
20	9:45	am	0.2	
21	8:10		0.2	
22	8:30		0.2	
23	8:10		0.2	
24	8:40		0.2	
25	8:20		0.2	
26	9:10		0.2	
27	9:30		0.2	
28	9:10		0.2	
29	8:45		0.2	
30	9:00		0.2	
31				

Was the chlorine residual ever less than the required minimum residual of 2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to ___ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>
--	--	---

Printed Name: Alix Keller Title: _____ Operator Certification #: N/A
 Signature: Alix Keller Phone #: (702) 535-6536 OR
 Date: 5/1/23 Small Groundwater System