

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Leafwood Water Assoc. PWS ID# 41 00993  
 Month/Year 9/23 Entry Point: Source AA Well Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:00 pm		.2	
2	10:00 AM		.2	
3	2:30 PM		.2	
4	12:30 PM		.2	
5	1:00 pm		.2	
6	9:00 am		.2	
7	8:15 am		.2	
8	8:20 am		.2	
9	8:15 am		.2	
10	8:30 am		.25	
11	8:00 am		.4	
12	8:30 am		.4	
13	8:30 am		.3	
14	9:00 am		.3	
15	9:10 am		.3	
16	9:00 am		.3	
17	9:30 am		.3	
18	9:10 am		.25	
19	8:40 am		.2	
20	2:00 pm		.2	
21	8:20 am		.35	
22	9:00 am		.3	
23	4:30 pm		.3	
24	11:14 am		.3	
25	9:00 am		.3	
26	8:20 am		.3	
27	8:15 am		.3	
28	9:20 am		.3	
29	9:00 am		.35	
30	8:45 am		.35	
31				

Was the chlorine residual ever less than the required minimum residual of .2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>	

Printed Name: Alix Geller Title: \_\_\_\_\_ Operator Certification #: N/A  
 Signature: Alix Geller Phone #: ( ) \_\_\_\_\_ OR  
 Date: 9/30/23 Small Groundwater System

**RECEIVED**  
 OCT 05 2023  
 Data Mgmt & Compliance  
 Drinking Water Program