


State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name:	Bella Casa Mobile Home Park	PWS ID#	41 - 01005
Month/Year:	October 2022	Entry Point:	Required Minimum Residual: 0.60 mg/L
		Kitchen Sink in Rec Rm	

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.80	
2	10:00:00 AM	WELL (L15434)	0.87	
3	10:00:00 AM	WELL (L15434)	0.73	
4	10:00:00 AM	WELL (L15434)	0.65	
5	6:00:00 AM	WELL (L15434)	0.63	
6	2:00:00 PM	WELL (L15434)	0.70	
7	10:00:00 AM	WELL (L15434)	1.12	
8	6:00:00 AM	WELL (L15434)	0.80	
9	6:00:00 PM	WELL (L15434)	0.66	
10	6:00:00 PM	WELL (L15434)	0.61	
11	6:00:00 PM	WELL (L15434)	0.73	
12	6:00:00 PM	WELL (L15434)	0.96	
13	10:00:00 AM	WELL (L15434)	0.93	
14	10:00:00 AM	WELL (L15434)	0.86	
15	6:00:00 AM	WELL (L15434)	0.75	
16	2:00:00 PM	WELL (L15434)	0.63	
17	2:00:00 PM	WELL (L15434)	0.69	
18	6:00:00 AM	WELL (L15434)	0.92	
19	6:00:00 AM	WELL (L15434)	0.93	
20	6:00:00 PM	WELL (L15434)	0.88	
21	10:00:00 AM	WELL (L15434)	1.16	
22	10:00:00 AM	WELL (L15434)	0.98	
23	2:00:00 PM	WELL (L15434)	0.90	
24	6:00:00 AM	WELL (L15434)	0.82	
25	6:00:00 AM	WELL (L15434)	0.72	
26	6:00:00 AM	WELL (L15434)	0.65	
27	10:00:00 AM	WELL (L15434)	0.78	
28	2:00:00 PM	WELL (L15434)	1.28	
29	2:00:00 PM	WELL (L15434)	1.27	
30	6:00:00 PM	WELL (L15434)	1.25	
31	2:00:00 PM	WELL (L15434)	0.79	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p style="text-align: center;">GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to .60 mg/L?</p> <p><i>Attach those results and submit them with this form.</i></p>	<p style="text-align: center;">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: Dan Reitz Signature:  Date: 11/1/2022	Title: Vice President Oregon Water Services, Inc. Phone#: (541) 342-1718	Operator Certification #: D:6528, T:6528 OR Small Ground Water System
--	--	---