

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems


System Name: Bella Casa Mobile Home Park **PWS ID#** 41 - 01005

Month/Year: January 2025 **Entry Point:**
Kitchen Sink in Rec Rm **Required Minimum Residual:** 0.60 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.85	
2	10:00:00 AM	WELL (L15434)	0.80	
3	10:00:00 AM	WELL (L15434)	0.90	
4	10:00:00 AM	WELL (L15434)	0.85	
5	6:00:00 AM	WELL (L15434)	0.77	
6	2:00:00 PM	WELL (L15434)	0.69	
7	10:00:00 AM	WELL (L15434)	0.80	
8	6:00:00 AM	WELL (L15434)	0.90	
9	6:00:00 PM	WELL (L15434)	0.85	
10	6:00:00 PM	WELL (L15434)	0.76	
11	6:00:00 PM	WELL (L15434)	0.79	
12	6:00:00 PM	WELL (L15434)	0.88	
13	10:00:00 AM	WELL (L15434)	0.92	
14	10:00:00 AM	WELL (L15434)	0.95	
15	6:00:00 AM	WELL (L15434)	0.80	
16	2:00:00 PM	WELL (L15434)	0.85	
17	2:00:00 PM	WELL (L15434)	0.79	
18	6:00:00 AM	WELL (L15434)	0.63	
19	6:00:00 AM	WELL (L15434)	0.68	
20	6:00:00 PM	WELL (L15434)	0.71	
21	10:00:00 AM	WELL (L15434)	0.85	
22	10:00:00 AM	WELL (L15434)	0.80	
23	2:00:00 PM	WELL (L15434)	0.70	
24	6:00:00 AM	WELL (L15434)	0.65	
25	6:00:00 AM	WELL (L15434)	0.70	
26	6:00:00 AM	WELL (L15434)	0.63	
27	10:00:00 AM	WELL (L15434)	0.69	
28	2:00:00 PM	WELL (L15434)	0.70	
29	2:00:00 PM	WELL (L15434)	0.68	
30	6:00:00 PM	WELL (L15434)	0.69	
31	2:00:00 PM	WELL (L15434)	0.64	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours <i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No continuous monitoring equipment was returned to service? <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous Date it was returned / /</p>
---	---	---

<p>Printed Name: Dan Reitz</p> <p>Signature: </p> <p>Date: 2/3/2025</p>	<p>Title: Vice President</p> <p>Oregon Water Services, Inc.</p> <p>Phone#: (541) 342-1718</p>	<p>Operator Certification #: D:6528, T:6528</p> <p>OR</p> <p>Small Ground Water System</p>
--	---	--