

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: Bella Casa Mobile Home Park **PWS ID#** 41 - 01005


Month/Year: March 2025 **Entry Point:** Kitchen Sink in Rec Rm **Required Minimum Residual:** 0.60 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.88	
2	10:00:00 AM	WELL (L15434)	0.78	
3	10:00:00 AM	WELL (L15434)	0.90	
4	10:00:00 AM	WELL (L15434)	0.92	
5	6:00:00 AM	WELL (L15434)	1.02	
6	2:00:00 PM	WELL (L15434)	0.98	
7	10:00:00 AM	WELL (L15434)	0.99	
8	6:00:00 AM	WELL (L15434)	0.92	
9	6:00:00 PM	WELL (L15434)	0.85	
10	6:00:00 PM	WELL (L15434)	0.93	
11	6:00:00 PM	WELL (L15434)	1.20	
12	6:00:00 PM	WELL (L15434)	1.06	
13	10:00:00 AM	WELL (L15434)	0.98	
14	10:00:00 AM	WELL (L15434)	0.97	
15	6:00:00 AM	WELL (L15434)	0.95	
16	2:00:00 PM	WELL (L15434)	0.93	
17	2:00:00 PM	WELL (L15434)	0.98	
18	6:00:00 AM	WELL (L15434)	1.28	
19	6:00:00 AM	WELL (L15434)	1.19	
20	6:00:00 PM	WELL (L15434)	0.99	
21	10:00:00 AM	WELL (L15434)	0.95	
22	10:00:00 AM	WELL (L15434)	0.90	
23	2:00:00 PM	WELL (L15434)	0.88	
24	6:00:00 AM	WELL (L15434)	1.10	
25	6:00:00 AM	WELL (L15434)	0.95	
26	6:00:00 AM	WELL (L15434)	0.97	
27	10:00:00 AM	WELL (L15434)	0.94	
28	2:00:00 PM	WELL (L15434)	0.95	
29	2:00:00 PM	WELL (L15434)	0.93	
30	6:00:00 PM	WELL (L15434)	0.90	
31	2:00:00 PM	WELL (L15434)	0.89	

Was the chlorine residual ever less than the required minimum residual of .60 mg/L ____ Yes X No

If yes, what was the longest time period until the required level was restored? ____ hours

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours <i>Attach those results and submit them with this form.</i>	GWS Serving More Than 3,300 reporting month? ____Yes ____No continuous monitoring equipment was returned to service? <i>Attach grab sample results and submit them with this form.</i>	Date continuous Date it was returned / /
--	--	--

Printed Name: Dan Reitz Signature:  Date: 3/31/2025	Title: Vice President Oregon Water Services, Inc. Phone#: (541) 342-1718	Operator Certification #: D:6528, T:6528 OR Small Ground Water System
--	--	---