## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Bella Casa Mobile Home Park		PWS ID# 41 - 01005	
Month/Year:		May 2025	Entry Point: Kitchen Sink in Rec Rm	Required Minimum Residual: 0.60 mg/L	
Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Note	es
1	2:00:00 PM	WELL (L15434)	0.90		
2	10:00:00 AM	WELL (L15434)	0.95		
3	10:00:00 AM	WELL (L15434)	0.99		
4	10:00:00 AM	WELL (L15434)	1.08		
5	6:00:00 AM	WELL (L15434)	0.98		
6	2:00:00 PM	WELL (L15434)	0.95		
7	10:00:00 AM	WELL (L15434)	1.01		
8	6:00:00 AM	WELL (L15434)	0.85		
9	6:00:00 PM	WELL (L15434)	0.95		
10	6:00:00 PM	WELL (L15434)	1.03		
11	6:00:00 PM	WELL (L15434)	0.98		
12	6:00:00 PM	WELL (L15434)	0.86		
13	10:00:00 AM	WELL (L15434)	0.90		
14	10:00:00 AM	WELL (L15434)	0.88		
15	6:00:00 AM	WELL (L15434)	0.85		
16	2:00:00 PM	WELL (L15434)	0.90		
17	2:00:00 PM	WELL (L15434)	0.98		
18	6:00:00 AM	WELL (L15434)	0.92		
19	6:00:00 AM	WELL (L15434)	0.85		
20	6:00:00 PM	WELL (L15434)	0.90		
21	10:00:00 AM	WELL (L15434)	1.07		
22	10:00:00 AM	WELL (L15434)	1.10		
23	2:00:00 PM	WELL (L15434)	0.98		
24	6:00:00 AM	WELL (L15434)	0.97		
25	6:00:00 AM	WELL (L15434)	0.95		
26	6:00:00 AM	WELL (L15434)	0.91		
27	10:00:00 AM	WELL (L15434)	0.85		
28	2:00:00 PM	WELL (L15434)	0.79		
29	2:00:00 PM	WELL (L15434)	0.86		
30	6:00:00 PM	WELL (L15434)	0.88		
31	2:00:00 PM	WELL (L15434)	0.93		
Was the chlorine residual ever less than the required minimum residual of .60 mg/L YesX No If yes, what was the longest time period until the required level was restored? hours					
GWS Serving 3,300 or Fewer			GWS Serving More Than 3,300		Data continuous
If yes, did you monitor every four hours Attacn tnose results and submit tnem with this					Date continuous
form			continuous monitoring equipment was returned to service?  Date it was returned		
Attach grab sample results and submit them with this form. / / Printed Name: Dan Reitz Title: Vice President					
rinte	u Maille.	Dan Reitz		Operator Cartification	#. D.6520 T.6520
Signature			Oregon Water Services, Inc. Phone#: (541) 342-1718	Operator Certification #: D:6528, T:6528 OR	
Date: 6/6/2025				Small Ground Water System	