

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**


<b>System Name:</b>		Bella Casa Mobile Home Park		<b>PWS ID#</b> 41 - 01005	
<b>Month/Year:</b>		June 2025		<b>Entry Point:</b> Kitchen Sink in Rec Rm	
				<b>Required Minimum Residual:</b> 0.60 mg/L	

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.90	
2	10:00:00 AM	WELL (L15434)	0.89	
3	10:00:00 AM	WELL (L15434)	0.91	
4	10:00:00 AM	WELL (L15434)	0.87	
5	6:00:00 AM	WELL (L15434)	0.99	
6	2:00:00 PM	WELL (L15434)	0.90	
7	10:00:00 AM	WELL (L15434)	0.95	
8	6:00:00 AM	WELL (L15434)	0.93	
9	6:00:00 PM	WELL (L15434)	0.88	
10	6:00:00 PM	WELL (L15434)	0.95	
11	6:00:00 PM	WELL (L15434)	0.94	
12	6:00:00 PM	WELL (L15434)	0.96	
13	10:00:00 AM	WELL (L15434)	0.95	
14	10:00:00 AM	WELL (L15434)	0.89	
15	6:00:00 AM	WELL (L15434)	0.86	
16	2:00:00 PM	WELL (L15434)	0.70	
17	2:00:00 PM	WELL (L15434)	0.78	
18	6:00:00 AM	WELL (L15434)	0.89	
19	6:00:00 AM	WELL (L15434)	0.90	
20	6:00:00 PM	WELL (L15434)	0.92	
21	10:00:00 AM	WELL (L15434)	0.93	
22	10:00:00 AM	WELL (L15434)	0.98	
23	2:00:00 PM	WELL (L15434)	0.80	
24	6:00:00 AM	WELL (L15434)	0.79	
25	6:00:00 AM	WELL (L15434)	0.75	
26	6:00:00 AM	WELL (L15434)	0.95	
27	10:00:00 AM	WELL (L15434)	0.96	
28	2:00:00 PM	WELL (L15434)	0.80	
29	2:00:00 PM	WELL (L15434)	0.79	
30	6:00:00 PM	WELL (L15434)	0.77	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** \_\_\_ Yes \_\_\_ **X** No  
 If yes, what was the longest time period until the required level was restored? \_\_\_ hours

<b>GWS Serving 3,300 or Fewer</b>  If yes, did you monitor every four hours <i>Attach those results and submit them with this form</i>	<b>GWS Serving More Than 3,300</b>  reporting month? ___ Yes ___ No continuous monitoring equipment was returned to service? <i>Attach grab sample results and submit them with this form.</i>	Date continuous Date it was returned /      /
---	--	---

Printed Name: Dan Reitz  Signature:   Date: 7/7/2025	Title: Vice President Oregon Water Services, Inc. Phone#: (541) 342-1718	Operator Certification #: D:6528, T:6528 OR Small Ground Water System
---	--	---