


State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

<b>System Name:</b> Bella Casa Mobile Home Park		<b>PWS ID#</b> 41 - 01005	
<b>Month/Year:</b> July 2025		<b>Entry Point:</b> Kitchen Sink in Rec Rm	<b>Required Minimum Residual:</b> 0.60 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.82	
2	10:00:00 AM	WELL (L15434)	0.87	
3	10:00:00 AM	WELL (L15434)	0.85	
4	10:00:00 AM	WELL (L15434)	0.79	
5	6:00:00 AM	WELL (L15434)	0.80	
6	2:00:00 PM	WELL (L15434)	0.75	
7	10:00:00 AM	WELL (L15434)	0.83	
8	6:00:00 AM	WELL (L15434)	0.89	
9	6:00:00 PM	WELL (L15434)	0.90	
10	6:00:00 PM	WELL (L15434)	1.07	
11	6:00:00 PM	WELL (L15434)	0.95	
12	6:00:00 PM	WELL (L15434)	0.80	
13	10:00:00 AM	WELL (L15434)	0.75	
14	10:00:00 AM	WELL (L15434)	0.65	
15	6:00:00 AM	WELL (L15434)	0.75	
16	2:00:00 PM	WELL (L15434)	0.70	
17	2:00:00 PM	WELL (L15434)	0.87	
18	6:00:00 AM	WELL (L15434)	1.08	
19	6:00:00 AM	WELL (L15434)	1.02	
20	6:00:00 PM	WELL (L15434)	1.00	
21	10:00:00 AM	WELL (L15434)	1.10	
22	10:00:00 AM	WELL (L15434)	1.01	
23	2:00:00 PM	WELL (L15434)	0.92	
24	6:00:00 AM	WELL (L15434)	0.85	
25	6:00:00 AM	WELL (L15434)	1.10	
26	6:00:00 AM	WELL (L15434)	1.03	
27	10:00:00 AM	WELL (L15434)	1.00	
28	2:00:00 PM	WELL (L15434)	0.90	
29	2:00:00 PM	WELL (L15434)	1.53	
30	6:00:00 PM	WELL (L15434)	1.31	
31	7:00:00 PM	WELL (L15434)	0.90	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** \_\_\_\_ Yes ☒ No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<b>GWS Serving 3,300 or Fewer</b> If yes, did you monitor every four hours <i>Attach those results and submit them with this form</i>	<b>GWS Serving More Than 3,300</b> reporting month? ____ Yes ____ No continuous monitoring equipment was returned to service? <i>Attach grab sample results and submit them with this form.</i>	Date continuous Date it was returned / /
---	--	--

Printed Name: Dan Reitz Signature:  Date: 8/6/2025	Title: Vice President Oregon Water Services, Inc. Phone#: (541) 342-1718	Operator Certification #: D:6528, T:6528 OR Small Ground Water System
---	--	---