

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: Bella Casa Mobile Home Park **PWS ID#** 41 - 01005

Month/Year: January 2026 **Entry Point:**
Kitchen Sink in Rec Rm **Required Minimum Residual:** 0.60 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	1.50	
2	10:00:00 AM	WELL (L15434)	1.88	
3	10:00:00 AM	WELL (L15434)	1.98	
4	10:00:00 AM	WELL (L15434)	1.96	
5	6:00:00 AM	WELL (L15434)	1.54	
6	2:00:00 PM	WELL (L15434)	1.61	
7	10:00:00 AM	WELL (L15434)	1.78	
8	6:00:00 AM	WELL (L15434)	1.76	
9	6:00:00 PM	WELL (L15434)	2.20	
10	6:00:00 PM	WELL (L15434)	1.20	
11	6:00:00 PM	WELL (L15434)	1.15	
12	6:00:00 PM	WELL (L15434)	1.30	
13	10:00:00 AM	WELL (L15434)	1.20	
14	10:00:00 AM	WELL (L15434)	1.01	
15	6:00:00 AM	WELL (L15434)	0.98	
16	2:00:00 PM	WELL (L15434)	1.16	
17	2:00:00 PM	WELL (L15434)	1.10	
18	6:00:00 AM	WELL (L15434)	1.19	
19	6:00:00 AM	WELL (L15434)	2.04	
20	6:00:00 PM	WELL (L15434)	2.05	
21	10:00:00 AM	WELL (L15434)	2.10	
22	10:00:00 AM	WELL (L15434)	2.20	
23	2:00:00 PM	WELL (L15434)	2.18	
24	6:00:00 AM	WELL (L15434)	2.16	
25	6:00:00 AM	WELL (L15434)	1.56	
26	6:00:00 AM	WELL (L15434)	1.50	
27	10:00:00 AM	WELL (L15434)	1.45	
28	2:00:00 PM	WELL (L15434)	1.40	
29	2:00:00 PM	WELL (L15434)	1.80	
30	6:00:00 PM	WELL (L15434)	2.10	
31	7:00:00 PM	WELL (L15434)	1.40	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours <i>Attach those results and submit them with this form</i></p>	<p>GWS Serving More Than 3,300</p> <p>reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No continuous monitoring equipment was returned to service? <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous Date it was returned / /</p>
--	---	---

<p>Printed Name: Dan Reitz</p> <p>Signature: </p> <p>Date: 2/2/2026</p>	<p>Title: Vice President</p> <p>Oregon Water Services, Inc.</p> <p>Phone#: (541) 342-1718</p>	<p>Operator Certification #: D:6528, T:6528</p> <p>OR</p> <p>Small Ground Water System</p>
--	---	--