

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Casey's Riverside RV Park

PWS ID# 4 1 01007

Month/Year JAN/2021

Entry Point: SRC-AC

Required Minimum Residual .72 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:30	Pavilion	1.9	
2	12:05	Pool	2.0	
3	7:10	House	2.0	
4	11:22	#56	2.0	
5	11:45	Clubhouse	1.9	
6	12:18	Pavilion	1.9	
7	10:42	Pool	1.3	
8	6:50	House	1.9	
9	9:35	#56	1.8	
10	11:15	Clubhouse	1.7	
11	2:13	Pavilion	1.7	
12	9:55	Pool	1.7	
13	7:10	House	1.5	
14	11:40	#56	1.4	
15	12:48	Clubhouse	1.3	
16	10:05	Pavilion	1.3	
17	11:28	Pool	1.2	
18	7:00	House	1.1	
19	10:22	#56	1.1	
20	12:38	Clubhouse	1.2	
21	11:25	Pavilion	1.2	
22	10:50	Pool	1.2	
23	6:44	House	1.1	
24	11:30	#56	1.1	
25	12:13	Clubhouse	1.2	
26	10:55	Pavilion	1.2	
27	10:18	Pool	1.2	
28	4:45	House	1.2	
29	9:30	#56	1.2	
30	10:42	Clubhouse	1.2	
31	11:05	Pavilion	1.3	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.


Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Andre Yazdi

Signature: 

Date: 02/01/2021 2021

Title: Owner/Operator

Phone #: (541) 782-1906

Operator Certification #:

OR

Small Groundwater System