

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Casey's Riverside RV Park

PWSID# 41 01007

Month/Year MAY/ 2022

Entry Point: SRC-AC

Required Minimum Residual 0.2 mg/L



Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:20	Pavilion	1.3	
2	9:16	Pool	1.4	
3	2:40	House	1.4	
4	11:38	#56	1.4	
5	2:22	Clubhouse	1.3	
6	11:05	Pavilion	1.3	
7	11:41	Pool	1.3	
8	6:30	House	1.3	
9	2:55	#56	1.2	
10	12:00	Clubhouse	1.2	
11	11:10	Pavilion	1.2	
12	4:35	Pool	1.2	
13	6:30	House	1.3	
14	11:00	#56	1.3	
15	2:22	Clubhouse	1.4	
16	1:16	Pavilion	1.4	
17	12:41	Pool	1.4	
18	6:20	House	1.5	
19	3:50	#56	1.5	
20	11:20	Clubhouse	1.6	
21	2:58	Pavilion	1.6	
22	10:00	Pool	1.6	
23	6:10	House	1.5	
24	2:22	#56	1.5	
25	1:30	Clubhouse	1.5	
26	11:05	Pavilion	1.5	
27	12:49	Pool	1.6	
28	6:00	House	1.6	
29	3:19	#56	1.6	
30	11:40	Clubhouse	1.5	
31	10:21	Pavilion	1.5	

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ NoIf yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or FewerIf yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

// //

Date it was returned to service:

// //

Printed Name: Andre Yazdi

Owner/Operator

Operator Certification #: 4328

Signature: 

Phone #: (541-782-1906)

OR

Small Groundwater System X

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.