

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Casey's Riverside RV Park

PWS ID# 41 01007

Month/Year Nov/2024

Entry Point: SRC-AC

Required Minimum Residual  .72 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:29	Pavilion	1.1	
2	10:38	Pool	1.1	
3	6:45	House	1.0	
4	12:11	#56	1.0	
5	1:41	Clubhouse	1.0	
6	3:05	Pavilion	1.0	
7	9:00	Pool	0.9	
8	6:42	House	0.9	
9	11:10	#56	0.9	
10	10:14	Clubhouse	1.0	
11	2:41	Pavilion	1.0	
12	10:24	Pool	0.9	
13	6:46	House	0.9	
14	1:50	#56	0.8	
15	10:56	Clubhouse	0.9	
16	2:29	Pavilion	1.0	
17	10:00	Pool	1.1	
18	6:50	House	1.0	
19	10:16	#56	1.1	
20	9:38	Clubhouse	1.5	
21	10:51	Pavilion	1.8	
22	9:31	Pool	1.9	
23	10:16	House	2.0	
24	10:25	#56	2.1	
25	9:43	Clubhouse	2.1	
26	10:42	Pavilion	2.2	
27	9:54	Pool	2.2	
28	10:17	House	2.2	
29	10:19	#56	2.3	
30	9:31	Clubhouse	2.0	
31	10:46	Pavilion	1.9	

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No

If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or FewerIf yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300Did continuous monitoring equipment fail at any time this reporting month? Yes NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /
Date it was returned to service:

/ /

Printed Name: Angie Yazdi

Title: Owner/Operator

Operator Certification #:

Signature: 

Phone #: (541) 782-1906

OR

Date: 12/07/2024

Small Groundwater System