

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Casey's Riverside RV Park

PWS ID# 41 01007

Month/Year Aug/2025

Entry Point: SRC-AC

Required Minimum Residual .72 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:48	Pavilion	1.6	
2	10:48	Pool	1.6	
3	7:00	House	1.7	
4	11:10	#56	1.7	
5	2:33	Clubhouse	1.8	
6	1:00	Pavilion	1.7	
7	8:40	Pool	1.8	
8	6:50	House	1.9	
9	10:00	#56	2.0	
10	10:20	Clubhouse	1.9	
11	2:00	Pavilion	1.7	
12	8:22	Pool	1.5	
13	6:20	House	1.1	
14	3:11	#56	1.0	
15	11:55	Clubhouse	1.0	
16	11:10	Pavilion	1.1	
17	11:36	Pool	1.1	
18	9:40	House	1.0	
19	2:00	#56	.9	
20	8:30	Clubhouse	.8	
21	11:42	Pavilion	.9	
22	9:00	Pool	1.0	
23	6:30	House	1.0	
24	10:12	#56	1.1	
25	2:16	Clubhouse	1.0	
26	11:49	Pavilion	1.0	
27	8:10	Pool	.9	
28	6:00	House	.9	
29	10:49	#56	.9	
30	11:50	Clubhouse	1.0	
31	4:00	Pavilion	1.0	

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ NoIf yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or FewerIf yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Andre Yazdi

Signature:

Date: 09/01/2025

Title: Owner/Operator

Phone #: (541) 782-1906

Operator Certification #:

OR

Small Groundwater System ☒