

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**



System Name ROGUE RIVER PINES PARK PWS ID# 41 01D17
 Month/Year 11/21 Entry Point: STORAGE TANK BLDG Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:35 PM	WELL #2	0.5	
2	1:20 PM	WELL #2	0.5	
3	4:50 PM	WELL #2	0.10	
4	12:10 PM	WELL #2	0.5	
5	3:40 PM	WELL #2	0.5	
6	4:35 PM	WELL #2	0.5	
7	11:55 AM	WELL #2	0.10	
8	4:10 PM	WELL #2	0.5	
9	3:30 PM	WELL #2	0.10	
10	4:00 PM	WELL #2	0.6	
11	3:15 PM	WELL #2	0.6	
12	2:40 PM	WELL #2	0.5	
13	12:25 PM	WELL #2	0.5	
14	10:35 AM	WELL #2	0.5	
15	4:20 PM	WELL #2	0.5	
16	3:30 PM	WELL #2	0.5	
17	3:50 PM	WELL #2	0.4	
18	2:25 PM	WELL #2	0.5	
19	3:35 PM	WELL #2	0.5	
20	2:50 PM	WELL #2	0.10	
21	3:55 PM	WELL #2	0.6	
22	2:20 PM	WELL #2	0.5	
23	4:15 PM	WELL #2	0.6	
24	3:35 PM	WELL #2	0.6	
25	4:20 PM	WELL #2	0.5	
26	3:50 PM	WELL #2	0.5	
27	1:25 PM	WELL #2	0.4	
28	12:40 PM	WELL #2	0.4	
29	3:15 PM	WELL #2	0.5	
30	2:10 PM	WELL #2	0.5	
31				

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
---	---

Printed Name: ERNEST G. FRUTKIN Title: OWNER Operator Certification #: _____
 Signature: [Signature] Phone #: (541) 582-1371
 Date: 12/03/21

OR
Small Groundwater System