

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name ROGUE RIVER PINES PARK PWS ID# 41 01017
 Month/Year 02/22 Entry Point STORAGE TANK BLDG Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:35pm	WELL #2	0.5	
2	1:20pm	WELL #2	0.6	
3	3:10pm	WELL #2	0.6	
4	4:30pm	WELL #2	0.5	
5	2:20pm	WELL #2	0.5	
6	1:45pm	WELL #2	0.5	
7	3:00pm	WELL #2	0.5	
8	4:50pm	WELL #2	0.5	
9	12:15pm	WELL #2	0.5	
10	4:20pm	WELL #2	0.6	
11	3:25pm	WELL #2	0.6	
12	4:55pm	WELL #2	0.5	
13	2:40pm	WELL #2	0.5	
14	11:15am	WELL #2	0.5	
15	4:20pm	WELL #2	0.5	
16	1:05pm	WELL #2	0.6	
17	2:50pm	WELL #2	0.5	
18	3:40pm	WELL #2	0.5	
19	2:15pm	WELL #2	0.5	
20	12:40pm	WELL #2	0.4	
21	3:10pm	WELL #2	0.5	
22	11:25am	WELL #2	0.5	
23	1:40pm	WELL #2	0.4	
24	4:00pm	WELL #2	0.5	
25	4:45pm	WELL #2	0.5	
26	2:30pm	WELL #2	0.4	
27	1:20pm	WELL #2	0.5	
28	3:40pm	WELL #2	0.5	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach these results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>	

Printed Name: ERNEST G BRITTON SR Title: OWNER Operator Certification #: _____
 Signature: [Signature] Phone #: (541) 582-7374
 Date: 03/03/22
 Small Groundwater System