

State of Oregon Drinking Water Program  
 Monthly Disinfection Report for Ground Water Systems

System Name McKee Bridge M.H.P. PWS ID# 41 01165  
 Month/Year 05/21 Entry Point: well Required Minimum Residual 50 mg/L

Date	Time	Source(s) In use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	5:05	#1 well	2.05	
2	7:00	#1 well	2.05	
3	6:45	#1 well	2.10	
4	6:30	#1 well	2.15	
5	4:45	#1 well	2.08	
6	7:10	#1 well	2.00	
7	6:18	#1 well	2.05	
8	6:05	#1 well	2.13	
9	5:00	#1 well	1.95	
10	9:10	#1 well	1.94	
11	5:30	#1 well	1.94	
12	6:10	#1 well	2.05	
13	6:30	#1 well	1.87	
14	7:12	#1 well	2.05	
15	8:00	#1 well	1.95	
16	7:00	#1 well	1.95	
17	7:00	#1 well	1.95	
18	3:18	#1 well	1.96	
19	6:14	#1 well	1.96	
20	7:05	#1 well	1.96	
21	6:30	#1 well	1.94	
22	6:44	#1 well	1.82	
23	8:00	#1 well	1.90	
24	7:06	#1 well	1.84	
25	6:15	#1 well	1.84	
26	6:42	#1 well	1.71	
27	7:02	#1 well	1.67	
28	8:30	#1 well	1.68	
29	8:31	#1 well	1.71	
30	8:00	#1 well	1.92	
31	7:44	#1 well	1.96	

Was the chlorine residual ever less than the required minimum residual of 50 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored?      Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to      mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:     /    /      
 Date it was returned to service:     /    /    

Printed Name: Steven Krudicka Title:       
 Signature: Steven Krudicka Phone #: (541) 899-7189  
 Date: 06/09/21

Operator Certification #:       
 OR  
 Small Groundwater System