

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Mckeel Bridge M.H.P. PWS ID# 4101165  
 Month/Year 11/23 Entry Point: \_\_\_\_\_ Required Minimum Residual .50 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:30	#1 well	0.5	
2	4:00	#1 well	0.5	
3	1:00	#1 well	0.6	
4	10:00	#1 well	0.5	
5	8:30	#1 well	0.5	
6	11:00	#1 well	0.5	
7	4:30	#1 well	0.5	
8	11:30	#1 well	0.5	
9	7:41	#1 well	0.5	
10	10:00	#1 well	0.6	
11	6:30	#1 well	0.5	there was NO water to test from 11-24-23 to 11-26-23
12	5:10	#1 well	0.5	
13	3:00	#1 well	0.5	
14	8:30	#1 well	0.5	CONTACT Mark 541-210-2984
15	9:40	#1 well	0.5	
16	10:30	#1 well	0.5	
17	4:10	#1 well	0.5	
18	2:18	#1 well	0.5	
19	1:00	#1 well	0.5	
20	10:15	#1 well	0.6	
21	12:00	#1 well	0.5	
22	9:00	#1 well	0.5	
23	8:00	#1 well	0.4	
24	1:30	N/A	N/A	
25	1:00	N/A	N/A	
26	1:00	N/A	N/A	
27	2:30	#1 well	0.2	
28	3:10	#1 well	0.2	
29	1:00	#1 well	0.4	
30	5:30	#1 well	0.4	
31				

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours -- If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to .50 mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form. <u>NO WATER</u></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>
---	--	---

Printed Name: Steven Krupicka Title: water tester Operator Certification #: \_\_\_\_\_  
 Signature: [Signature] Phone #: (541) 210-2984 OR \_\_\_\_\_  
 Date: 12/04/2023 541 951-3901 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dnce@state.or.us](mailto:dwp.dnce@state.or.us); fax 971-673-0694; or by mail to: Drinking Water Program, PO Box 14350, Portland, OR 97223-0350.