## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name WESTERN HILLS M			HESTATES	PWS ID# 4 1 01172		
Month/Year July/2023 Entry Point: D Required Minimum Residual 0.40 mg/L						
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L	)	Notes
1	11:00P	Wells 5&6		0.68		
2	11:00P	Wells 5&6		0.62		
3	03:04P	Wells 5&6		0.42		
4	05:00P	Wells 5&6		0.11		
5	12:50A	Wells 5&6		0.23		
6	12.10A	Wells 5&6		0.47		
7	01:00A	Wells 5&6		0.66		
8	12:00A	Wells 5&6		1.51		
9	12:00A	Wells 5&6		2.04		
10	12:00A	Wells 5&6		2.23		
11	01:00A	Wells 5&6		2.27		
12	05:00P	Wells 5&6		2.29		
13	12:00P	Wells 5&6		2.22		
14	05:00P	Wells 5&6		2.17		
15	02:00P	Wells 5&6		2.10		
16	12:00P	Wells 5&6		2.00		
17	06:00P	Wells 5&6		1.91		
18	05:00P	Wells 5&6		1.79		
19	12:00P	Wells 5&6		1.76		
20	06:00P	Wells 5&6		2.31		
21	03:00P	Wells 5&6		2.09		
22	02:00P	Wells 5&6		2.06		
23	11:00A	Wells 5&6		1.96		
24	10:00P	Wells 5&6		1.86		
25	05:00P	Wells 5&6		1.80		
26	11:00P	Wells 5&6		1.73		
27	06:00P	Wells 5&6		1.56		
28	04:00P	Wells 5&6		1.36		
29	03:00P	Wells 5&6		1.24		
30	10:00A	Wells 5&6		1.15		
31	02:20P	Wells 5&6		0.58		
Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L?  Yes  No  If yes, what was the longest time period until the required level was restored? 14 hours – If > 4 hours, Drinking Water Program to be						
notified by end of next business day.						
		<u>.                                      </u>		GWS Serving More Than 3,300		
GWS Serving 3,300 or Fewer  If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required?						
			Did continuous monitoring equipment fail at a reporting month?  Yes No		iny time this	Date continuous monitoring equipment failed:
					' '	
			If yes, were grab samples collected every four hours until the			Data it was returned to
Attach those results and submit them with this form.			continuous monitoring equipment was returned to service as required?			
ano tottii.			Attach grab sample results and submit them with this form.			
Attaun grau sample results and saumit them with this form.						, ,
Printed Name: JJ Olson			Title: Compliance Manager		Operator Certification #: 766039	
Signature:			Phone #: (503) 554-8333		OR	
Date: 08	3 / 03 / 2023	1 W 1			Small Gr	oundwater System