State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name WESTERN HILLS MH ESTATES PWS ID# 4 1 01172						
Month/	Year Aug	gus/2023 Entry Po	int: D	Required Minimum Residual 0.40 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	11:00A	Wells 5&6		0.64		
2	06:00P	Wells 5&6		0.69		
3	10:00P	Wells 5&6		0.55		
4	10:50A	Wells 5&6		0.52		
5	05:40P	Wells 5&6		0.53		
6	06:10P	Wells 5&6		0.49		
7	02:50P	Wells 5&6		0.46		
8	04:00P	Wells 5&6		0.91		
9	07:00P	Wells 5&6		0.85		
10	06:00P	Wells 5&6		0.77		
11	05:00P	Wells 5&6		0.72		
12	12:00P	Wells 5&6		0.66		
13	11:00A	Wells 5&6		0.62		
14	10:30P	Wells 5&6		0.59		
15	06:20A	Wells 5&6		0.40		
16	11:00A	Wells 5&6		0.47		
17	12:00A	Wells 5&6		0.92		
18	06:00A	Wells 5&6		1.09		
19	12:00P	Wells 5&6		1.10		
20	11:00P	Wells 5&6		1.06		
21	11:00P	Wells 5&6		0.99		
22	04:00P	Wells 5&6		0.87		
23	11:00P	Wells 5&6		0.79		
24	11:00P	Wells 5&6		0.64		
25	04:00P	Wells 5&6		0.51		
26	12:00A	Wells 5&6		1.11		
27	02:00A	Wells 5&6		1.22		
28	04:00P	Wells 5&6		1.32		
29	01:00A	Wells 5&6		1.33		
30	10:00P	Wells 5&6		1.23		
31	11:00P	Wells 5&6		1.01		
Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? Yes No						
If yes, what was the longest time period until the required level was restored? 0 hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required?			Did continuous monitoring equipment fail at any time this reporting month? No Date continuous monitoring equipment failed: If yes, were grab samples collected every four hours until the			
Attach those results and submit them with			continuous monitoring equipment was returned to service as			Date it was returned to
this form.			required?			service:
Attach grab sample results and submit them with this form.						
Printed Name: JJ Olson			Title: Compliance Manager		Operator Certification #: 766039	
Signatur	re:	Grey Olson	Phone #: (503) 554-8333		OR	
	9 / 06 / 2023				Small Groundwater System	